HOK-M-93 Page **1** of **66**



SBP BANKING SERVICES CORPORATION ENGINEERING DEPARTMENT HEAD OFFICE KARACHI

CONTINUOUS AND UN-INTERRUPTED MANAGEMENT SERVICES OF SCREW TYPE CHILLERS INSTALLED

AT

BSC HOUSE PLANT AND 3RD FLOOR, MAIN BANK BUILDING, STATE BANK OF PAKISTAN, KARACHI

BIDDING AND CONTRACT DOCUMENTS VOLUME-I

INVITATION TO BID
INSTRUCTIONS TO BIDDERS
BID DATA SHEET
FORM OF BID
QUALIFICATION CRITERIA
CONDITIONS OF CONTRACT
STANDARD FORM
SCOPE OF SERVICES/BILL OF QUANTITIES

JANUARY 2023



HOK-M-93 Page **2** of **66**



SBP BANKING SERVICES CORPORATION (SBP BSC)

Invitation to Bids (IFB)

"As per published tender notice in Newspaper, PPRA & SBP websites"



HOK-M-93 Page **3** of **66**

Sr. No. DESCRIPTION

- 1. Title Page
- 2. Invitation to Bids
- 3. Index
- 4. Bidding Documents Section-I (Instructions to Bidders)
- 5. Bidding Documents Section-II (Bid Data Sheet)
- 6. Bidding Documents Section-III- (Form of Technical Bid)
- 7. Bidding Documents Section-IV- (Qualification Criteria)
- 8. Bidding Documents Section-V- (Form of Financial Bid) (Attached as Volume II)
- 9. Bidding Documents Section-VI-Part 1 (Specific Services Data/ Scope of Services)
- 10. Bidding Documents Section-VI-Part-2- (General & Special Conditions of Contract)
- 11. Bidding Documents Section VII-Service Management Plan of Service Provider
- 12. Bidding Documents Section VIII-Forms of Contract

HOK-M-93 Page **4** of **66**

(Bidding Documents-Section-I)

INSTRUCTIONS TO BIDDERS

TABLE OF CONTENTS

Description

Clause No.

A. INTRODUCTION

- 1 Scope of Bid
- 2 Eligible Bidders
- 3 Qualification of the Bidder
- 4 One Bid per Bidder
- 5 Cost of Bidding

B. BIDDING DOCUMENTS

- 6 Contents of Bidding Documents
- 7 Clarification of Bidding Documents and Pre-bid Meeting
- 8 Amendment of Bidding Documents

C. PREPARATION OF BID

- 9 Language of Bid
- 10 Documents Comprising the Bid
- 11 Bid Prices
- 12 Currency of Bid and Payment
- 13 Bid Validity
- 14 Bid Security
- 15 Format, Signing and Submission of Bid

D. SUBMISSION OF BID

- 16 Sealing and Marking of Bids
- 17 Deadline for Submission of Bids
- 18 Late Bids
- 19 Modification and Withdrawal of Bids

E. BID OPENING AND EVALUATION

- 20 Bid Opening
- 21 The Process to be Confidential
- 22 Clarification of Bids
- 23 Preliminary Evaluation
- 24 Correction of Errors
- 25 Evaluation and Comparison of Bids
- 26 Contacting the Bank

F. AWARD OF CONTRACT

- 27 Award Criteria
- 28 Bank's Right to reject all the Bids
- 29 Bank's Right to Vary Inputs / Outputs at Time of Award
- 30 Notification of Award and Signing of Agreement
- 31 Disqualification Prior to Contract Signing
- 32 Performance Guarantee
- 33 Advance Payment and Security
- 34 Grievances Redressal
- 35 Code of Conduct
- 36 Overriding Effect of PPR-2004
- 37 Beneficial Ownership Information



HOK-M-93 Page **5** of **66**

Section - I INSTRUCTIONS TO BIDDERS

A. Introduction

	A. Introduction
1. Scope of Bid	1.1. SBP Banking Services Corporation, having its principal place of
	business as defined in Bid Data Sheet, (hereinafter called "SBP BSC")
	invites Bids for the Services summarized in the Bid Data Sheet
	(BDS) (hereinafter referred to as "the Services"), at the Buildings
	and other areas specified in the BDS (hereinafter referred to as
	Premises).
	1.2. Bidders must quote for the complete scope of Services. Any Bid
	covering partial scope of Services will be declared non-responsive.
	1.3. The procurement title, reference number, method and procedure
	are specified in the BDS.
2. Eligible	2.1. Except as provided in Instructions to Bidders Clauses 2.3, 2.4 and
Bidders	2.5, this bidding process is open to all bidders who meet the
Diducis	qualification criteria given in Bidding Documents.
	2.2. Joint Ventures and Consortiums shall not be permitted to submit the
	bid.
	2.3. Bidder already engaged by the SBP BSC for providing consultancy
	services related to the above procurement (if applicable) will not be
	eligible for bidding.
	2.4. A bidder declared ineligible for corrupt and fraudulent practices
	under Rule 19 of PPR-2004, shall not be permitted to submit the bid.
	The bidder must not be blacklisted by any Federal or Provincial
	Government Department, National Counter Terrorism Authority
	(NACTA), Agency, Organization, or Autonomous Body anywhere in
	Pakistan.
	2.5. A bidder who has been declared blacklisted or debarred by a foreign
	country, international organization, or other foreign institutions
	shall be treated as blacklisted and debarred from participating. Any
	bidder who has violated the law of land of any country and recorded
	in any sanction list will not be eligible to participate in the
	bidding/procurement process.
	2.6. Bidders shall provide evidence of their continued eligibility
	satisfactory to the SBP BSC, as the SBP BSC shall reasonably request.
	2.7. Bidder must meet all the qualification criteria as defined in Bidding
	Documents.
2 Qualification	
3. Qualification	3.1. All bidders shall provide, Form of Bid and Qualification Information,
of the Bidder	as required in BDS.
	3.2. To qualify for the award of the Contract, bidders must meet the
	mandatory evaluation criteria, as specified in the Bidding
4 0	Documents.
4. One Bid per	4.1 Each Bidder shall submit only one Bid individually.
Bidder	4.2. A bidder who submits or participates in more than one bid will be
	disqualified.
5. Cost of Bidding	5.1. The Bidder shall bear all costs associated with the preparation and
	submission of its bid, and the SBP BSC in no case be held responsible
	or liable for those costs, regardless of the conduct or outcome of the
	bidding process.
	B. Bidding Document
6. Content of	6.1. The given contents of the Bidding Documents subscribe to Rule 23

6.	Content	of	6.1. The given contents of the Bidding Docum	ents subscribe to Rule 23	
	Bidding		of PPR 2004. These should be read i	n conjunction with any	
	Documents		addendum issued under ITB Clause 8:		
			 Invitation to Bids. 	SANK OF PA	
			ii. Instructions to Bidders (ITB)		
				// #/ /#- \ - \ - \	

HOK-M-93 Page **6** of **66**

- iii. Bid Data Sheet (BDS)
- iv. Form of Bid
- v. Form of Contract
- vi. General Conditions of Contract (GCC)
- vii. Special Conditions of Contract (SCC)
- viii. Bill of Quantities/Description of Services
- ix. Bid Evaluation Criteria
- x. Format of Security Forms
- 6.2. Bidders are expected to examine all instructions, forms, terms, specifications, and other information in the Bidding Documents.
- 6.3. Failure to furnish all information required by the Bidding Documents or to submit a bid not substantially responsive to the Bidding Documents in every respect will be at the Bidder's risk and may result in the rejection of its bid.

7. Clarification of Bidding Documents and Pre-bid Meeting

- 7.1. A prospective Bidder requiring any clarification of the Bidding Documents may approach SBP BSC in writing at the given address and by one of the means indicated in the BDS. The SBP BSC will respond in writing to any request for clarification of the Bidding Documents that it receives no later than seven (07) days before the deadline of submission of bids. Copies of the SBP BSC's response (including an explanation of the query but not identifying its source) will be sent to all prospective Bidders that received the Bidding Documents from the SBP BSC
- 7.2. Under the provision of Rule 48 of PPR 2004, if a Bidder feels that any provision in the documents is contrary to the provisions of procurement regulatory framework, such issue should be raised as soon as possible. Any party may file its written complaint against the eligibility parameters, evaluation criteria, or any other terms and conditions prescribed in the Bidding Documents, if found contrary to the provisions of the procurement regulatory framework, the same shall be addressed by the Grievance Redressal Committee (GRC) well before the Bid submission deadline. The details of GRC is given on the PPRA website: www.ppra.org.pk and as provided in Bid Data Sheet (BDS).
- 7.3. As specified in the BDS, the SBP BSC will organize and Bidders are welcome to attend a Pre-bid meeting at the time and place indicated in the BDS. The purpose of the meeting will be to clarify issues and answer questions on any matter that may be raised at this stage, with particular attention to issues related to the Technical Requirements. Minutes of the meeting, including the questions raised and responses given, together with any responses prepared after the meeting, will be transmitted without delay to all those that received the Bidding Documents from the SBP BSC. Any modification to the Bidding Documents listed in ITB Clause 6.1, which may become necessary as a result of the pre-bid meeting, shall be made by the SBP BSC by issuing an Addendum under ITB Clause 8.

HOK-M-93 Page **7** of **66**

8. Amendment of Bidding Documents

- 8.1. At any time before the deadline for submission of bids, SBP BSC, for any reason, either at its initiative or in response to a clarification requested by a prospective Bidder, amend the Bidding Documents. Such amendments shall take precedence over the existing document.
- 8.2. Any addendum issued including the notice of any extension of deadline shall be part of the Bidding Documents pursuant to ITB 8.1 and shall be communicated in writing that provide record of the content of communication to all the bidders who have obtained the Bidding Documents from the Procuring Agency. The Procuring Agency shall promptly publish the Addendum at the Procuring Agency's web page (www.sbp.org.pk).
- 8.3. Provided that the bidder who had either already submitted their bid or handed over the bid to the courier prior to the issuance of any such addendum shall have the right to withdraw his already filed bid and submit the revised bid prior to the original or extended bid submission deadline.
- 8.4. The addendum will be binding on Bidders. It will be assumed that the amendments contained in such Addendum will have been taken into account by the Bidder in its bid.
- 8.5. To provide prospective Bidders reasonable time to take the amendments into account in preparing their bids, SBP BSC may, at its discretion, extend the deadline for the submission of bids consistent with the provision of Rule 27 of PPR 2004.

C. Preparation of Bids

9. Language of Bid

9.1. The bid prepared by the bidder and all correspondence and documents relating to the Bid, exchanged by the bidder and SBP BSC shall be written in the English or Urdu language; provided that any printed literature furnished by the bidder in another language as long as accompanied by an English or Urdu translation of its pertinent passages in which case, for purposes of interpretation of the Bid, the English or Urdu translation shall govern the relation between the parties.


10. Documents Comprising the Bid

- 10.1. The bid submitted by the Bidder shall comprise the following:
 - i. Forms for Technical Bid under Section III
 - ii. Documents related to Minimum Eligibility/Qualification Criteria under Section IV
 - iii. Forms for Financial Bid under Section V.
 - iv. Bidding Documents (in original) duly signed and stamped on each page / sheet.
 - v. Bid Security in original/Bid Securing Declaration.
 - vi. Power of Attorney in accordance with the Clause 15 of ITB.
 - vii. Any other materials/ services required to be completed and submitted by bidders, as specified in the Bid Data Sheet.

Page **8** of **66** HOK-M-93

11. Bid Prices	11.1.The Bidder shall quote rates and prices for all items of the Services
	described in the scope of services, and as listed in the Price
	Schedule. Items for which no rate or price is entered by the Bidder
	will not be paid for by the SBP BSC when the contract is executed
	and shall be deemed covered by other rates and prices in the
	Activity Schedule.
	11.2.All duties, taxes, liabilities including overheads, transportation
	charges etc. and other levies payable by the Bidder under the
	Contract, or for any other cause shall be included in the total Bid
	price submitted by the Bidder. Any new indirect tax or duty levied
	by the Government during the bidding process shall be adjusted/
	included in the bid price. The exemption in Taxes will only be
	allowed against an Exemption Certificate issued by the respective
	Department.
	11.3.If provided for in the Bidding Data Sheet, the rates and prices
	quoted by the Bidder shall be subject to adjustment during the
	performance of the Contract in accordance with and the provisions
	of Clause 5.2 of the General Conditions of Contract and/or Special
	Conditions of Contract.
12. Currencies of	12.1.The price shall be quoted by the Bidder in Pak Rupees and the
Bid and	payments to be made by SBP BSC would be in Pak Rupees.
Payment	payments to be made by 5D1 D5G would be in 1 ak Rupees.
13. Bid Validity	13.1.Bids shall remain valid for the period specified in the BDS.
13. Dia variatty	13.2.In exceptional circumstances, SBP BSC may request the bidders to
	extend the bid validity period for a specified additional period. The
	request and the bidders' responses shall be made in writing by
	letter or email. A Bidder may refuse the request without forfeiting
	the Bid Security. A Bidder agreeing to the request will not be
	required or permitted to otherwise modify the Bid, but will be
	required to extend the validity of Bid Security for the period of the
	extension, and in compliance with ITB Clause 14 in all respects.
14. Bid Security	14.1. The bid security shall be denominated in the currency of the bid:
	i. at the Bidder's option, be in the form of either Pay
	Order/demand draft/call deposit or an unconditional Bank
	Guarantee from a Scheduled Bank;
	ii. be substantially in accordance with one of the formats of bid
	security included in bidding documents or other form
	approved by the SBP BSC before bid submission;
	iii. be payable promptly upon written demand by the SBP BSC;
	iv. be submitted in its original form; copies will not be accepted;
	v. In the case of Bank Guarantee, it shall remain valid for at least
	28 days beyond the original validity period of bids, or at least
	28 days beyond any extended period of bid validity
	subsequently requested under ITB Clause 13.2.
	vi. Bids submitted with insufficient bid security will be rejected.
	vii. Bid security of unsuccessful bidders will be released/
	returned after the conclusion of the procurement process, as
	soon as possible, upon receipt of the nomination to receive
	the instrument.
	viii. The most advantageous Bidder's bid security will be
	released/ returned upon the submission of performance
	Guarantee.
	14.2.The bid security may be forfeited:
	i. If a bidder withdraws his bid during the period of bid
	validity; or
	ii. If a bidder does not accept the correction of his Bid Production
For Bidder (Sign and Stamp)	Ear Dall State of Carlot
roi biudei (Sigii and Stamp)	For Bank Science As The Design of the Control of th

HOK-M-93 Page **9** of **66**



inner envelopes shall indicate the name and address of the Bidder to enable the Bid to be returned unopened in case it is declared late,

16.3.If the outer envelope is not sealed and marked as above, the SBP BSC will assume no responsibility for the misplacement or

under ITB Clause 18.

premature opening of the Bid.

HOK-M-93 Page **10** of **66**

17. Deadline for	17.1.Bids must be received (through an authorized representative or
Submission of	courier/postal service) by SBP BSC at the address specified in the
Bids	BDS, no later than the bid submission deadline specified in the BDS.
	Bids submitted through telegraph, telex, fax or e-mail shall not be
	considered. Any bid received by the SBP BSC after the deadline for
	submission prescribed in the Bid Data Sheet will be returned
	unopened to such bidder.
	17.2. SBP BSC may extend the deadline for submission of bids by issuing
	an amendment under ITB Clause 8 , in which case all rights and
	obligations of the SBP BSC and the bidders previously subject to the
	original deadline will then be subject to the new deadline.
18. Late Bids	18.1.Any Bid received (through an authorized representative or
10. Late Dius	courier/postal service) by SBP BSC after the deadline prescribed in
	ITB Clause 17 will be returned unopened to the Bidder.
19. Modification	19.1.The Bidder may modify or withdraw its bid after the bid's
and	submission, provided that written notice of the modification,
Withdrawal of	
Bids	including substitution or withdrawal of the bids, is received by the
Dius	SBP BSC before the deadline prescribed for submission of bids
	under ITB Clause 17.
	19.2.No bid can be modified after the deadline for submission of bids.
	19.3.No bid can be withdrawn in the interval between the deadline for
	submission of bids and the expiry of the period of bid validity,
	specified by the Bidder on the Bid Form. Withdrawal of a bid during
	this interval will result in the Bidder's forfeiture of its bid security.
00 010	E. Bid Opening and Evaluation
20. Bid Opening	20.1. The Bank will open all bids, including modifications, in public, in the
	presence of Bidder's representatives who choose to attend, at the
	time, on the date, and at the place specified in the BDS.
	20.2.For in person meeting, the bidders' representatives shall sign an
24 57	attendance sheet as proof of their participation.
21. The process to	21.1.The disclosure of information relating to the examination,
Be	clarification, evaluation, comparison of bids and recommendations
Confidential	for the award of a contract shall be subject to Rule 41 of PPR-2004 .
	21.2.Information relating to evaluation of bids and recommendations
	concerning to award of the contract shall not be disclosed by SBP
	BSC to the bidders or to any other person who is not officially
	concerned with the process, until the announcement of the result of
	evaluation.
	21.3. The Bidder shall not disclose or attempt to make public any
	information relating to the bidding documents, bidding process and
	award of the contract to any person or entity without SBP BSC's
	prior written consent.
	21.4.In case of any disclosure related to the bidding process and
	contractual obligations at any stage by any bidder and/or service
	provider, SBP BSC may reject its bid and/or terminate the contract.
	21.5. Any effort by a Bidder to influence the Bank in its decisions on bid
	evaluation, bid comparison, or contract award may result in the
	rejection of the Bidder's bid.
22. Clarification of	, , , , , , , , , , , , , , , , , , , ,
Bids	Bidder for clarification of its bid. The request for clarification and
	the response shall be in writing, and no change in the price (except
	under Clause 24 of ITB) or substance of the bid shall be sought,
	offered, or permitted.



HOK-M-93 Page **11** of **66**

23. Preliminary 23.1. The Bank will examine the bids to determine whether: **Examination** they are complete. bid validity is provided accordingly, iii. required bid security/bid securing declaration have been furnished. the documents have been properly signed. iv. the bids are generally in order: Bidder has provided all forms of Technical Bid under Section III and relevant documents under Section IV 23.2.Bidders have to submit bids for **COMPLETE REQUIREMENTS**, partial and incomplete bids will be rejected. 23.3.Bids submitted without a signed Bid Form by the authorized nominee of the bidder will be rejected. 23.4. Bids with material deviation, exception, objection, conditionality, or reservation will be rejected. 23.5.Bids submitted late will also be rejected. 24. Correction of 24.1.Bids determined to be substantially responsive will be checked by the Bank for any arithmetic errors. Arithmetical errors will be **Errors** rectified by the Bank on the following basis: if there is a discrepancy between unit prices and the total price that is obtained by multiplying the unit price and quantity, the unit price shall prevail, and the total price shall be corrected, unless in the opinion of the Procuring Agency there is an obvious misplacement of the decimal point in the unit price, in which the total price as quoted shall govern and the unit price shall be corrected; if there is an error in a total corresponding to the addition or subtraction of sub-totals, the sub-totals shall prevail and the total shall be corrected; and Where there is a discrepancy between the amounts in figures and in words, the amount in words will govern. Where there is discrepancy between grand total of price schedule and amount mentioned on the Form of Bid, the amount referred in Price Schedule shall be treated as correct subject to elimination of other errors. 24.2. The amount stated in the Bid will be adjusted by the Bank as per the above procedure for the correction of errors and, with the concurrence of the Bidder, shall be considered as binding upon the Bidder. If the Bidder does not accept the corrected amount, the Bid will be rejected, and the Bid Security may be forfeited or the Bid Securing Declaration may be executed in accordance with **ITB 14**. 25. Evaluation 25.1. The technical bids of the only qualified bidders after preliminary and evaluation under ITB Clause 23, shall be evaluated in detail. 25.2.SBP BSC will evaluate and compare only the bids previously Comparison of **Bids** determined to be substantially responsive and qualified pursuant to **Sub-Clauses 23.2 of ITB to 23.5 of ITB** as per requirements given hereunder. Bids will be evaluated for complete scope of services. Any Bid covering partial scope of services will be declared nonresponsive. The prices will be compared on the basis of the Evaluated Bid Price and during evaluation of the bid's price, SBP BSC will determine for each bid in addition to the Bid Price, the following factors (adjustments) in the manner and to the extent indicated below to determine the Evaluated Bid Price: (a) Making any correction for arithmetic errors pursuant to Sub-BAHK OF PA Clause 24.2 of ITB hereof.

Page **12** of **66** HOK-M-93

	(b) Discount, if any, offered by the bidders as also read out and	
	recorded at the time of bid opening.	
	25.3.The submitted Technical Bid and other Commercial/Financial	
	Requirements of the bidding documents will be evaluated on	
	compliance based criteria.	
	25.4.The Financial Bids of the only technically accepted bids will be	
	opened and the bid found to be the Most Advantageous shall be	
	accepted.	
	25.5.Any minor informality, non-conformity or irregularity in a Bid	
	which does not constitute a material deviation may be waived by	
	SBP BSC, provided such waiver does not prejudice or affect the	
	relative ranking of any other bidders.	
26. Contacting the	26.1. Subject to Clause 22 of ITB heretofore, no bidder shall contact SBP	
Bank	BSC on any matter relating to its Bid from the time of the Bid	
	opening to the time the bid evaluation results are announced by SBP	
	BSC. The evaluation results shall be announced as under:	
	(a) Technical Evaluation Report/Results would be posted for	
	seven days on SBP's website/shared with participating	
	bidders.	
	(b) Financial / Final Evaluation Report would be posted on	
	PPRA and SBP websites for fifteen days.	
	26.2.Any bidder feeling aggrieved by any act of SBP BSC may lodge a	
	written complaint concerning his grievances as per Rule 48 of PPR-	
	2004.	

F. Award of Contract		
27. Award Criteria	27.1.The contract will be awarded to the most advantageous Bidder	
	whose bid has been found Technically & Commercially/Financially	
	compliant and emerged as the Most Advantageous i.e. the bid	
	which has been determined to be substantially responsive to the	
	eligibility criteria, compliant to applicable laws and other terms of	
	Bidding Documents and which is the lowest evaluated Bid Price.	
	Provided further that the Bidder is determined to perform the	
00 D 1/ D' 1	contract satisfactorily.	
28. Bank's Right to	28.1.SBP BSC reserves the right to annul the bidding process and reject	
Reject all the	all bids at any time before award of contract under Rule 33 of	
Bids	PPR-2004 without thereby incurring any liability to the affected	
	bidders or any obligation to inform the affected bidders of the grounds for such rejection. The grounds for rejection of all bids	
	shall upon request be communicated, to any bidder who submitted	
	a bid, but SBP BSC will not be liable to provide any justification for	
	the grounds of rejection. Notice of the rejection of all the bids shall	
	be given promptly to all the bidders.	
29. Bank's Right to	29.1. SBP BSC reserves the right at the time of contract award to	
Vary Inputs/	increase or decrease scope of services without any change in unit	
Outputs at	price or other terms and conditions, provided such variation	
Time of Award	should be in line with the provisions of PPR-2004.	
30. Notification of	30.1. Prior to the expiration of the period of initial/extended bid	
Award and	validity, the Bank will notify the most advantageous Bidder in	
Signing of	writing ("Notification of Award"), to be confirmed in writing by	
Agreement	registered letter/email, that its bid has been accepted.	
	30.2. Within twenty-one (21) days from the date of furnishing of	
	acceptable Performance Guarantee under the Conditions of	
	Contract, SBP BSC will send the most advantageous bidder the	
	Form of Agreement provided in the Bidding formations,	
	incorporating all agreements between the parties.	
	S CIVIL E	
For Bidder (Sign and Stamp)	For Ban (Someon San)	
	CYAKI METU	

Page **13** of **66** HOK-M-93

	20.2 ml		
	 30.3.The formal Agreement between SBP BSC and the most advantageous bidder shall be executed within seven (07) days of the receipt of Form of Agreement by the most advantageous bidder from SBP BSC. 30.4.Upon the most advantageous Bidder's furnishing of the 		
	Performance Guarantee and signing of Contract, SBP BSC will discharge its bid security.		
31. Disqualification	31.1.After issuance of Notification of Award and before execution of		
Prior to	procurement contract with the most advantageous bidder, if the		
Contract	Bidder has been disqualified pursuant to Rule 18 and Rule 19 of		
Signing	PPR-2004 or any other reason has led to the disqualification of the		
	most advantageous bidder or if the conditions of his qualification are invalid, the next Most Advantageous bidder will be considered as responsive provided accepting this bid does not conflict with applicable laws.		
	31.2. For rejecting the Most Advantageous bid and opting for the second		
	Most Advantageous bidder, an opportunity of being heard should be provided to the bidder with the Most Advantageous bid.		
32. Performance	32.1. After the receipt of Notification of Award, the most advantageous		
Guarantee	Bidder, within the specified time, shall deliver to the Procuring		
	Agency a Performance Security (or Guarantee) in the amount and in the form stipulated in the BDS.		
	32.2. Failure of the most advantageous Bidder to comply with the		
	requirement of ITB 32.1 shall constitute sufficient grounds for the		
	annulment of the award and forfeiture of the Bid Security, in which		
	event the Procuring Agency may make the award to the next		
	ranked Bidder or call for new Bids.		
33. Advance	33.1. SBP BSC will provide an Advance Payment on the Contract		
Payment and	Price if stipulated in the Special Conditions of the Contract.		
Security	24.1 Any hidder aggrigged by any act during the programent process		
34. Grievances Redressal	34.1.Any bidder aggrieved by any act during the procurement process may lodge a written complaint concerning his grievances to the Grievance Redressal Committee (GRC), as per Rule 48 of PPR-2004 . The details of GRC is given on the PPRA website: www.ppra.org.p and as given in Bid Data Sheet (BDS).		
35. Code of	35.1.It is the SBP BSC's policy to require that bidder shall observe the		
Conduct	highest standard of ethics during the procurement and execution of such contract. In pursuit of this policy, the SBP BSC follows, inter alia, the instructions contained in Rule 2(1)(f) of the PPR-2004 which defines:		
	"corrupt and fraudulent practices" in respect of		
	procurement process, shall be either one or any combination of		
	the practices including,- i. "coercive practices" which means any impairing or		
	harming or threatening to impair or harm, directly or		
	indirectly, any party or the property of the party to		
	influence the actions of a party to achieve a wrongful gain		
	or to cause a wrongful loss to another party;		
	ii. "collusive practices" which means any arrangement		
	between two or more parties to the procurement process		
	designed to stifle open competition for any wrongful gain, and to establish prices at artificial, non-competitive levels;		
	iii. "corrupt practices" which means the offering sixing,		
	receiving or soliciting, directly or indirectly, way to receive the acts of another party for weong		
For Diddor (Cian and Channe)	Civil E		
For Bidder (Sign and Stamp)	For Ban (Santa)		

HOK-M-93 Page **14** of **66**

gain

- iv. "fraudulent practices" which means any act or omission, including a misrepresentation, that knowingly or recklessly misleads, or attempts to mislead, a party to obtain a financial or other benefit or to avoid an obligation; and
- v. **"obstructive practices"** which means harming or threatening to harm, directly or indirectly, persons to influence their participation in a procurement process, or affect the execution of a contract;"
- 35.2.**Under** Rule **19 of PPR-2004**, the SBP BSC can inter alia blacklist the bidders found to be indulging in corrupt or fraudulent practices. Such barring action shall be duly publicized and communicated to the PPRA.
- 35.3.**Under Rule 19 of PPR-2004**, the following mechanism and manner for permanently or temporarily barring, from participating in their respective procurement proceedings will be followed as per the guidance of SBP BSC management:

Nature of Offense/ Fault	Means of Verification	
Corrupt and Fraudulent Practices	 Results of Bid/Proposal analysis resulting in substantive evidence of collusion. Actual instance verifiable as per law of land and applicable Rule and Regulations of SBP Banking Services Corporation Cross verification of documentary undertaking submitted by Service Provider. 	
Performance Deficiencies	Documented evidence in form of consistent performance deficiencies and notices of performance deficiencies not suitably responded to or defended by Service Provider.	
Bidder failed to abide with Bid Form / Bid Securing Declaration.	Failed to abide with Bid Form / Bid Securing Declaration.	

However, such barring action shall be undertaken only after providing an adequate opportunity of being heard to the bidder who is to be barred and blacklisted.

- 35.4. The **receipt** for any money paid by the bidders will not be considered as an acknowledgment of payment to the bidder unless such receipt is signed by a duly authorized officer of the SBP BSC and the bidder shall be solely responsible for seeing that a proper receipt is provided.
- 35.5.Under **Rule 7 of PPR 2004**, bidder undertakes to sign an Integrity pact in accordance with the prescribed format given in the Bidding document for all the procurements estimated to exceed Rs. 10.00 million or any other limit prescribed by SBP BSC.
- 35.6.SBP BSC's policy requires that selected bidder provide professional, objective, and impartial advice, supplies, and services and at all times hold the SBP BSC's interests' paramount strictly avoid conflicts with other assignments or their corporations and act without any consideration for future work.

For Bank

HOK-M-93 Page **15** of **66**

Γ	
	disclose any situation of actual or potential conflict that impacts their capacity to serve the best interest of the SBP BSC, or that may
	reasonably be perceived as having this effect. Failure to disclose
	said situations may lead to the disqualification of the bidder and
	termination of contract arising out of this procurement.
	35.7. Without limitation on the generality of the foregoing, bidders, and
	any of their affiliates shall be considered to have a conflict of
	interest and shall not be recruited, under any of the circumstances
	set forth below:
	i. A bidder that has been engaged by the SBP BSC to provide
	goods, works, or services other than consulting services for
	a project, and any of its affiliates, shall be disqualified from
	providing consulting services related to those goods, works,
	or services. Conversely, bidders providing consulting
	services for the preparation or implementation of a project,
	and any of its affiliates shall be disqualified from
	subsequently providing goods or works or services other
	than consulting services resulting from or directly related to
	the firm's consulting services for such preparation or implementation.
	ii. A bidder (including its Personnel) or any of its affiliates shall
	not be engaged for any assignment that, by its nature, may
	conflict with another assignment of the bidder to be
	executed for the same or another client.
	iii. A bidder (including its Personnel) that has a business or
	family relationship with a member of the SBP BSC's staff who
	is directly or indirectly involved in any part of
	a. the preparation of the specifications of the goods,
	b. the selection process for such assignment, or
	c. Supervision of the Contract may not be awarded a
	contract unless the conflict stemming from this
	relationship has been resolved in a manner acceptable to the appropriate authority within the SBP BSC.
	iv. Bidders shall not recruit or hire any agency or current
	employees of the SBP BSC. Recruiting former employees of
	the SBP BSC or other civil servants to work for the bidders is
	acceptable provided no conflict of interest exists. When the
	bidder nominates any government employee as Personnel in
	their bid, such Personnel must have written certification
	from their government or employer confirming that they are
	on leave without pay from their official position and allowed
	to work full-time outside of their previous official position.
	Such certification shall be provided to the SBP BSC by the
36. Overriding	bidder as part of the bid. 36.1.Whenever in conflict with these documents, the stipulation of
Effect of PPR-	PPR-2004 shall prevail.
2004	F
37. Beneficial	37.1.For Services/works worth Rs.50M or above, the bidder shall
Ownership	provide Beneficial Ownership information on the prescribed
Information	Form. Failure to provide the required information of the beneficial
	ownership by the company or submission of false or partial
	information, the procuring agency shall: (a) Blacklist the said company in accordance with rule 19(1)(a) of
	(a) Blacklist the said company in accordance with rule 19(1)(a) of Public Procurement Rules, 2004,
	(b) Reject the bid of the said company.
<u> </u>	

For Bank Signwision

HOK-M-93 Page **16** of **66**

Section II - Bid Data Sheet (BDS)

The following specific data for services to be procured shall complement, supplement or amend the provisions in the Instructions to Bidders (ITB). Whenever there is a conflict, the provisions herein shall prevail over ITB.

ITB	Description		
Clause			
1.1	• Procurement Title: Continuous and Un-Interrupted Management Services of		
	Screw Type Chillers installed at BSC House Plant and 3rd Floor, Main Bank		
	Building, State Bank of Pakistan, Karachi		
	• Reference Number: HOK-M-93		
	• Procurement Method: Open Competitive Bidding as per Rule 21 of PPR-2004		
	• Procurement Procedure: "Single Stage Two Envelopes Procedure" as per Rule-		
	36(b) of PPR-2004.		
7.3	No Pre-bid meeting will be held.		
13.1	Bid Validity period is 180 days from the date fixed for opening of the Bids.		
14.1	Bid Security of Amount as stated in Published Tender Notice in favor of SBP		
	BSC shall be enclosed along with the Technical Bid in the shape of Pay Order		
	/ Demand Draft /Deposit at Call in favor of SBP-Banking Service		
	Corporation valid for a period 28 days beyond the Bid Validity date. The Bid		
	Security in original is required to be submitted with Technical Bid.		
	Any bid found without sufficient Bid Security will be rejected instantly. (In		
	the case of a bank guarantee, the validity of the bank guarantee should be		
4 7 4	28 days beyond the bid validity period.)		
15.1	Only original Bid is to be submitted.		
16.1	1. The Original Bid shall comprise a single sealed package containing two separate sealed envelopes. Each envelope shall contain separately the Financial Proposal and the Technical Proposal. The inner envelopes shall be marked as "ORIGINAL TECHNICAL PROPOSAL" and "ORIGINAL FINANCIAL PROPOSAL" in bold letters.		
	2. The outer envelope shall be addressed to the Bank at the address given in the BDS, and carry the statement "DO NOT OPEN BEFORE [Date & Time of the Bid Submission Deadline]". The content of the Technical and Financial Proposal is mentioned in BDS.		
	3. Following should be the contents of the Technical Bid Envelope:		
	i. Form I of Section III – Authorization Form for Bidder's		
	Representative		
	ii. Form II of Section III – Form of Technical Bid		
	iii. Form III of Section III – Bid Security Form/Bank Guarantee: duly		
	filled and signed or Bid Security in the shape of Call		
	Deposit/Demand Draft/Payment Order or Bid Securing		
	Declaration.		
	iv. Form IV of Section III – Technical Compliance Form v. Form V of Section III – Undertaking		
	vi. Form VI – Declaration of Beneficial Owners' Information		
	vii. Duly signed and stamped, Volume-I of the Bidding document.		
	viii. All documents related to Minimum Eligibility/Qualification		
	Criteria including Annexure (If Any) under Section IV		
	4. Following should be the contents of the Financial Proposal		
	Envelope/Volume-II:		
	i. Form-I of Section V – Financial Bid Submission Form		

HOK-M-93 Page **17** of **66**

	ii. Duly filled, signed and stamped, Volume-II of the Bidding			
	, , ,			
	document			
	<u>Important Note:</u>			
	Above mentioned forms are pre-requisite, non-availability of the			
	above-mentioned documents will result in the rejection of a bid.			
17.1	The Bank's address for Bid submission is as mentioned in Notice for Invitation			
	to Bids (Published Tender Notice).			
	• The Bank will communicate the opening of the Financial Proposal to the			
	eligible/qualified bidders after the completion of all requirements of Technical			
	Evaluation.			
	The deadline for submission of bids shall be as mentioned in Notice for			
	Invitation to Bids.			
20.1				
	Bids will be opened as defined in Notice for Invitation to Bids. Compared to the compa			
29.1	• Fifteen percent (15%) increase or decrease in scope of services.			
32.1	The most advantageous Bidder shall furnish a Performance Guarantee equal			
	to 5% of the total contract price in the shape of Bank Guarantee/Bank draft			
	issued from a scheduled bank in Pakistan, which will be valid 28 days beyond			
	the Contract Period. The Performance Guarantee shall be forfeited if the most			
	advantageous Bidder fails to perform the services under the Contract.			
34.1	The address of Grievance Committee is;			
	Chairman Grievances Committee,			
	·			
	Office of the Director Human Resource Management Department,			
	1st Floor, BSC House State Bank of Pakistan Main Building Complex,			
	I.I.Chundrigar Road, Karachi			



HOK-M-93 Page **18** of **66**

Section III- Form for Technical Bid

- 1. Form I Authorization Form for Bidder's Representative
- 2. Form II Technical Bid Submission Form / Form of Bid
- 3. Form III Bid Security Form/Bank Guarantee
- 4. Form IV Technical Compliance Form
- 5. Form V Undertaking
- 6. Form VI Declaration of Beneficial Owners' Information



HOK-M-93 Page **19** of **66**

Form - I (Authorization Form for Bidder's Representative)

(ON SERVICE PROVIDER'S LETTERHEAD)

Date:

ITB No: HOK-M-93

Continuous and Un-Interrupted Management Services of Screw Type
Chillers installed at BSC House Plant and 3rd Floor, Main Bank Building,
State Bank of Pakistan, Karachi

We, M/s <Firm Title> , incorporated under <mention the relevant Act/ordinance/ regulation> having its registered office at <complete business address> do hereby nominate Mr./Ms. <Complete Name>, <Designation>, CNIC# <xxxxx-xxxxxxx-x> as our lawful representative to participate, negotiate, sign, correspond and fulfil all associated formalities of the subject procurement on our behalf.

Official Seal & Signature of Bidder:	
Date:	

HOK-M-93 Page **20** of **66**

Form – II (Technical Bid Submission Form / Form of Bid)

(Letter of Offer)

Bid Reference No. HOK-M-93

Continuous and Un-Interrupted Management Services of Screw Type Chillers installed at BSC House Plant and 3rd Floor, Main Bank Building, State Bank of Pakistan, Karachi To:

Gentle	men,
1.	Having examined the Bidding Documents including Addenda Nos for
	the execution of the above-named services, we, the undersigned, being a company/firm
	doing business under the name ofand address
	and being duly incorporated established under the laws of Pakistan hereby offer to execute
	the subject services and remedy any defects therein in conformity with the said Documents
	including Addenda thereto for the Total Bid Price as stated in Volume-II: Schedule of Prices
	or such other sum as may be ascertained in accordance with the said Documents.
	We understand that all the Schedules attached hereto form part of this Bid.
	As security for due performance of the undertakings and obligations of this Bid, we submit
	herewith a Bid Security as provided in Bid Data Sheet drawn in your favor or made payable
	to you and valid for a period of two hundred eight (208) days or Bid Securing Declaration
	as the case may be.
	We undertake, if we qualify and our Bid is accepted, to take up the subject services for the
	time period as stated in Bid Data Sheet.
	We agree to abide by this Bid for a period of 180 days from the date fixed for opening the
	same and it shall remain binding upon us and may be accepted at any time before the
	expiration of that period.
	Unless and until a formal contract is prepared and executed, this Bid, together with your
	written acceptance thereof, shall constitute a binding contract between us.
	We undertake, if our Bid is accepted, to execute and abide by the Performance Guarantee
	referred to in Conditions of Contract for the due performance of the Services.
	We understand that you are not bound to accept the lowest or any bid you may receive.
	We do hereby declare that the Bid is made without any collusion, comparison of figures or
	arrangement with any other person or persons making a bid for the Services.
	We do hereby declare that all the terms and conditions mentioned in the Bidding
	Documents are acceptable to us and we have no objection about any clause/sub-clause of
	the Conditions of Contract and other parts of the Bidding Documents.
Dated t	thisday of, 202
Signati	ure
	capacity ofduly authorized to sign the bid for and on behalf of the Bidder. A
letter c	of authorization in respect of the Person who has signed the Bid Form, etc. is also attached
-	of Bidder in Block Capitals)
(Seal)	
Addres	
Witnes	
	ture)
Name:	
Addres	SS:
C.N.I.C	No:

HOK-M-93 Page **21** of **66**

Form - III

(Bid Security Form)

(Bank Guarantee/ Not to be followed in case of Pay Order/CDR)

Over Stamp Paper

(Lette	r by the	Guaran	tor to SBP Bank	ing Services (Corporation	n (SBP BS0	C))		
Name addres		antor (S	cheduled Bank	in Pakistan) v	with				
Name	of Princ		dder) with						
			(express in wo						
Bid Re	ference	No		Date of E	3id				
of the Bankin the pa admin THE C accom	said Bi ng Servi yment o istrator ONDITI panying	dder, w ces Corp of which s and su ON OF g Bid r	HESE PRESENTS ye the Guaranto poration, (herein n sum well and nccessors, jointly THIS OBLIGATI numbered and SBP BSC; and	or above-namenafter referrence truly to be many and severall to the several to the seve	ned are hel ed to as "SB] nade, we bi ly, firmly by , that when	d and firm P BSC") in nd oursel y these pro- reas the E	mly bound the sum st ves, our he esents. Bidder has	I unto the SE cated above, for eirs, executor submitted th	RP or s,
WHER	EAS, SB	BP BSC ł	nas required as ty in the above :					at the Princip	al
(1)			ecurity shall ren lity of the bid;	nain valid for	a period of	twenty e	ight (28) da	ays beyond th	ıe
(2)	that in	the eve	ent;						
	(a) (b) (c)	the Pr	incipal withdray incipal does not of the most adv furnish the rec sign the propo	accept the covantageous bituined Perfor	orrection of idder to mance Gua	his Bid P	rice, or	l, or	

the entire sum be paid immediately to the said SBP BSC for delayed completion and not as penalty for the most advantageous bidder's failure to perform.

For Ban

NOW THEREFORE, if the most advantageous bidder shall, within the period specified therein, on the prescribed form presented to him for signature and enter into a formal Contract with SBP BSC in accordance with his Bid as accepted, and furnish within fifteen (15) days of receipt of Letter of Acceptance, a Performance Guarantee with good and sufficient surety , as may be required, upon the form prescribed by the said SBP BSC for the faithful performance and proper fulfillment of the said Contract or in the event of non-withdrawal of the said Bid within the time specified then this obligation shall be void and of no effect, but otherwise to remain in full force and effect.

HOK-M-93 Page **22** of **66**

PROVIDED THAT the Guarantor shall forthwith pay to SBP BSC the said sum stated above upon first written demand of SBP BSC without cavil or argument and without requiring SBP BSC to prove or to show grounds or reasons for such demand, notice of which shall be sent by SBP BSC by registered post/ courier service duly addressed to the Guarantor at its address given above.

PROVIDED ALSO THAT SBP BSC shall be the sole and final judge for deciding whether the Bidder has duly performed its obligations to sign the Contract and to furnish the requisite Performance Guarantee within the time stated above, or has defaulted in fulfilling said requirements and the Guarantor shall pay without objection the sum stated above upon first written demand from SBP BSC forthwith and without any reference to the Bidder or any other person.

IN WITNESS WHEREOF, the above bounded Guarantor has executed this guarantee under its seal on the date indicated above, the name and seal of the Guarantor being hereto affixed and these presents duly signed by its undersigned representative pursuant to authority of its governing body.

	Guarantor (Bank)
Witness:	1. Signature
1.	2. Name: 3. Title
2.	
(Name, Title and Address)	

HOK-M-93 Page **23** of **66**

Form IV (Technical Compliance Form)

(ON SERVICE PROVIDER'S LETTERHEAD)

Sr.#	Description	Bidder Response (Yes/No)
1	All the requirements mentioned in "Section-VI-Part I-"Specific Services Data/Scope of Services".	
2	All the stated Terms and Conditions of the Contract including BOQ and forms etc.	

Seal and Signature of Ridder:		

General Note

- The Minimum Eligibility / Technical Compliance will be evaluated totally on a compliance-based method. The Financial Proposal of the only technically accepted bids will be opened and the bid found to be the Most Advantageous bid shall be accepted.
- The bid found to be the Most Advantageous i.e. having qualified the minimum / technical criteria and offered the lowest evaluated cost shall be accepted and will be awarded the contract.



HOK-M-93 Page **24** of **66**

Form - V (Undertaking)

(Over Stamp Paper of Rs. 100)

Dear S	Sir,
--------	------

1.0	I/We, M/s, hereby undertake that I/We, M/s shall comply with all applicable Labor laws and other applicable laws which includes but not limited to following:
	a. Payment of at-least minimum wages/salaries/remuneration as notified by the respective Government.
	 Ensure EOBI/Social Security registration of its resources and regular payment of contributions.
	c. Group Life and Medical Insurance.d. Casual, medical and maternity or any other leaves as per applicable laws.
	e. Any other requirement as per applicable laws.
2.0	I/We, M/s, shall issue appointment letters to my employees working under this contract in compliance of the above stated laws.
3.0	I/We, M/s, understand and agree unconditionally that in case I/We, M/s fail to abide by the above undertaking or any of terms of the Contract, the Client/ SBP BSC shall be at liberty to terminate the Contract without prejudice to any other rights / remedy available in the Contract.
4.0	I/We hereby confirm and declare that I/We, M/s, has neither been Blacklisted/debarred under Rule 19 of PPR-2004 nor sanctioned by National Counter Terrorism Authority (NACTA).
5.0	Detection of false declaration/statement at any stage of the entire Bidding Process / Currency of the Contract shall lead to disqualification and forfeiture of Bid Security and/or Performance Guarantee and termination of the contract.
Seal &	& Signature of Bidder:
Date:	



HOK-M-93 Page **25** of **66**

Form - VI (Declaration of Beneficial Owners' Information)

In case of services/works worth Rs.50 million or above, the bidder shall provide Beneficial Ownership information on the below prescribed Form:

1.	Name	
2.	Father's Name/Spouse's Name	
3.	CNIC/NICOP/Passport no.	
4.	Nationality	
5.	Residential address	
6.	Email address	
7.	Date on which shareholding, control or interest acquired in the	
	business.	

8. In case of indirect shareholding, control or interest being exercised through intermediary companies, entities or other legal persons or legal arrangements in the chain of ownership or control, following additional particulars to be provided:

1	2	3	4	5	6	7	8	9	10
Name	Legal form (Company/ Limited Liability Partnership/ Association of Persons/ Single Member Company/ Partnership Firm/ Trust/Any other individual, body corporate (to be specified))	Date of incorporation/registration	Name of registering Authority	Business Address	Country	Email Address	Percentage of shareholding, control or interest of BO in the legal person or legal arrangement	Percentage of shareholding, control or interest of legal person or legal arrangement in the Company	Identity of Natural Person who ultimately owns or controls the legal person or arrangement

9. Information about the Board of Directors (details shall be provided regarding number of shares in the capital of the company as set opposite respective names).

1	2	3	4	5	6	7	8
Name and surname (In Block Letters)	CNIC No. (in case of foreigner, Passport No)	Father's/ Husband's Name in full	Current Nationality	Any other Nationality (ies)	Occupation	Residential address in full or the registered/ principal office address for a subscriber other than natural person	Number of shares taken by each subscriber (in figures and words)
						11=21	//s 1≫11

For Bank Signishon Saryo)

HOK-M-93 Page **26** of **66**

	Total number of shares taken (in figures and	
	words)	

10. Any other information incidental to or relevant to Beneficial Owner(s).

Name & signature

(Person authorized to issue notice on behalf of the company)



HOK-M-93 Page **27** of **66**

SECTION IV (SCHEDULE A TO BID) – QUALIFICATION INFORMATION AND BID EVALUATION CRITERIA

1. Basic Conditions for Qualification

1.1 Joint Ventures (JV) are not allowed, only firms/ companies fulfilling the requirements mentioned in the Invitation to Bid are eligible to participate in the bidding process.

- 1.2 Information supplied by the Bidders for the qualification statement must apply to the company, named on the statement only. The substitution of background information pertinent to qualification will not be considered for another company related to the applicant company through a "Group ownership". Financial Bids of only technically qualified bidders shall be opened and the Contract shall be awarded to the most advantageous bidder.
 - a) SBP BSC will review the information supplied by the bidders submitted for qualification and will make public the results of qualification to the bidders.
 - b) Firms/Companies applying for qualification are advised that any variation of constitution or membership from that put forward in response to this notice, without prior approval of SBP BSC may result in their disqualification.
 - c) The response to this notice must be sufficiently detailed to convince SBP BSC that the firms/companies applying for qualification have the experience as well as the technical, administration and financial qualifications necessary for the execution of the services and they must prove that they have carried out similar services in their own country or abroad.
 - d) Only Technical Proposals will be opened in the presence of Bidders or their authorized representatives who may choose to attend as per the schedule provided in the Invitation to Bids. The bidders should provide maximum information required for evaluation of their Technical Proposals.
 - e) The Financial Bids of the technically qualified bidders shall be opened on the date and venue communicated to the bidders through email/registered post/ courier service. The Financial Bids of the Bidder's, who fail to qualify, shall be returned to them unopened. Decision of SBP BSC in this connection shall be final and binding on all Bidders.

2. Qualification Criteria:

2.1 General

Qualification will be based on all the criteria given in paras **2.1 to 2.2** regarding the Bidder's general and particular experience, personnel and equipment capabilities, and financial position, as demonstrated by the Bidder's responses in the forms attached to this letter. SBP BSC reserves the right to waive minor deviations, if these don't materially affect the capability of Bidder to perform the contract.

SBP BSC reserves the right to verify or seek clarification of the information furnished by the Bidders. In this regard, Employer reserve the right to have site visit to verify the previous installation /work experience etc. SBP BSC may reject any application for any misrepresentation knowingly made by any bidder in, or pursuant to, their application or for any statement furnished in connection therewith, and intended to be relied upon by the SBP BSC, which is incorrect in any respect.

2.2 Qualification Criteria

In addition to the eligibility criteria given in the instructions to bidders, for qualification purpose, the bidders must meet the following requirements:

HOK-M-93 Page **28** of **66**

Sr.	Minimum Eligibility/	Means of verification	Attached
1.	Qualification Criteria Bid Security is required as per clause ITB-14.	Bid Security in Original is to be attached with Technical Proposal.	Original bid Security
2.	Bid is unconditional		
3.	Duly filled and signed Form of Bid		
4.	The bidder should be registered with relevant Tax authorities and appear on Active Tax payer list of FBR.	Attach copies of relevant Tax Registration Certificate and proof of being on ATL of FBR. (SBP BSC will also verify that the bidder name is appearing in online active taxpayer list)	Copies of relevant Tax Registration Certificate & proof of being on ATL of FBR
5.	The Bidder should also be registered with relevant / concerned Revenue Authority. If not registered, the 100% tax shall be deducted at source as per applicable law and credited to relevant account.		Copies of relevant Tax Registration Certificate
6.	The bidder should submit an undertaking that the bidder has never been blacklisted or debarred by any organization, is not in the sanctioned list of NACTA (National Counter Terrorism Authority and will comply all applicable laws	Undertaking required on stamp paper of Rs.100/- as per format provided in Form – V	Undertaking required on stamp paper of Rs.100/- as per format provided in Form - V
7.	Proposed Services Execution Plan of the Bidder	Duly filled Methodology/ Program of Performing the Services provided in Schedule E to bid	Duly filled Methodology / Program of Performing the Services in schedule E to bid
8.	Available Financial Capability/ Liquid Assets of the firm	Provide Bank statement showing required balance of Minimum Liquid assets of Rs.0.60 Million at any one instance in three months period or credit line facility available during same period.	Bank statement produced between date of publication of tender notice and bid submission date.
9.	General Experience of providing HVAC services	Minimum of 05 Years of Services experience. The bidder must provide "Letter of Award/ Contract agreement/ Taking Over/ Completion Certificate" of the projects of which the experience is being claimed.	Required Documents fulfilling criteria



HOK-M-93 Page **29** of **66**

10.	Particular Experience of the Firm	Services provided amounting	
		to minimum of Rs. 2.0	
		Million/year/contract (at least	
		02 contracts during last five	
		(05) years).	Required Documents
		The bidder must provide	fulfilling criteria
		Work orders/ Completion	J
		certificates/ contract	
		agreements etc. of the	
		projects of which experience	
		is being claimed.	

HOK-M-93 Page **30** of **66**

Section V- Form for Financial Bid (Volume II)

Provided in Volume-II of Bidding Documents



HOK-M-93 Page **31** of **66**

Form II - (SCHEDULE B TO BID) Price Schedule (Volume II) The Financial Bid

Provided as Volume-II of Bidding Documents



HOK-M-93 Page **32** of **66**

SECTION-VI- (SCHEDULE C TO BID) PART-1 SPECIFIC SERVICES DATA/ SCOPE OF SERVICES

1. <u>Scope of Services :</u>

The service provider shall be responsible for the continuous and uninterrupted management services of the complete HVAC System (Chillers, cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves, allied piping and its complete electrical system) including Plant Room, service & maintenance of all equipment controls, components and accessories including repair, preventive maintenance and annual service.

2. <u>List of Equipment:</u>

Services are required at the following major equipment:

S No.	Plant Details:	Capacity	Make	Location
1.	Air cooled Screw Type Chiller	150 TR	York	
	and allied Equipment			
2.	Air cooled Screw Type Chiller	150 TR	York	
	and allied Equipment			
3.	Centrifugal Pumps with	15 – 25 KW	Siemens	
	Motors x 03 No.			SBP BSC Building
4.	01 Lot Electric Panels with	-	-	
	Breakers, control circuits,			
	complete with all accessories			
5.	01 Lot Piping Systems for	-	-	
	chilled water complete with all			
	accessories valves, makeup			
	tank etc.			
6.	Air cooled Screw Type Chiller	150 TR	York	SBP Main Building, 3rd
	and allied Equipment			Floor
7.	Centrifugal Pumps with	15 – 25 KW	Siemens	
	Motors x 02 No.			
8.	01 Lot Electric Panels with	-	-	
	Breakers, control circuits,			
	complete with all accessories			
9.	01 Lot Piping Systems for	-	-	
	chilled water complete with all			
	accessories valves, makeup			
	tank etc.			

3. <u>Services Schedule:</u>

The following service execution schedule shall be followed:

Sr No	Nature of Service	Execution Schedule	
1.	Supervisory Services at HVAC Plant and inside the Building	Monday to Saturday 06:30PM	from 07:30AM to
2.	Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers		KANK OF PARTY
			//*/ <i>\</i>

HOK-M-93 Page **33** of **66**

	and Allied Piping	
3.	Technical Assistance Services	
4.	Technical Support (On call) Services including Troubleshooting, Inspections, Preventive and Corrective	As per preventive and corrective maintenance requirement and requirements shared by Client (including Weekends and Holidays)
	Services for HVAC system and Allied Equipment	

4. <u>Details & Frequency of Services:</u>

Services:

The major items of Services under this Contract are as follows:

Please note that spare parts and material required for continuous operation & maintenance services and for major repairs and annual servicing shall be provided by the Client along with following:

- Electricity and water supply.
- Supply of Water treatment chemicals, paints & special lubricants or oils.
- Provision of suitable space for Service Provider within or close to Plant Room with a telephone extension for easy communication with the concerned officials of the Client

However, the Service Provider has to maintain at the premises, necessary tools/equipment and safety equipment required for said service.

General	General Services		
i.	The Service Provider shall provide services for smooth and uninterrupted operation as well as maintenance, services and general upkeep for the above listed equipment.		
ii.	Maintenance services for complete HVAC System (Chillers, cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves, allied piping and its complete electrical system) including Plant Room cleaning and maintenance		
iii.	Services for immediate removal and appropriate disposal of waste, such as empty cans, scales of treated water, filters and of other such items according to municipal codes and environmental standards		
iv.	The periodical and preventive maintenance/service of the HVAC Plant and allied equipment shall be carried out on daily/monthly/bi-annual/yearly etc. basis and as per the service manuals of the manufactures in presence of the Client's representative and details of these shall be duly entered in the daily log sheets/book. The Service Provider shall complete the annual servicing, maintenance, repairs and service during this period so that the equipment are in full working order following service. Checklists and reports for the services must be submitted to the Client.		
V.	Services for cleaning and general upkeep of Chillers, Pumps, motors, piping, allied valves, Electrical distribution plant room, and surrounding areas.		
vi.	Dosing water treatment chemicals		
vii.	Removal and fixing of false ceiling as required by the Service Provider for carrying out his work. The Service Provider shall be responsible for making good any damage to the false ceiling framing and tiles		
viii.	The Service Provider shall ensure that the HVAC plant is operated, maintained & serviced efficiently to avoid breakdown during normal operation. The Service Provider shall also ensure economical consumption of the materials & spare parts		
ix.	The temperature on each floor at different locations shall be roughly at least twice daily.		

Page **34** of **66** HOK-M-93

plant and Allied Equipment on priority basis and if required the maintenance services for rectification of equipment may be provided after office hours or on holiday(s) to set right the service, or at any time due to exigencies/ emergencies and will provide services for smooth working in the minimum possible time. The Service Provider shall inform the Client well in advance about any maintenance/repair/service work scheduled to be done by the Service Provider after office hours or on holiday(s). Xiii. A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), if required. A) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted.		
out by the Service Provider who will immediately convey any abnormality in HVAC Plant and Allied Equipment, as well as make immediate arrangements to set right such abnormalities. xii. The Service Provider shall attend maintenance or repair work of the HVAC plant and Allied Equipment on priority basis and if required the maintenance services for rectification of equipment may be provided after office hours or on holiday(s) to set right the service, or at any time due to exigencies/ cmergencies and will provide services for smooth working in the minimum possible time. The Service Provider shall inform the Client well in advance about any maintenance/repair/service work scheduled to be done by the Service Provider after office hours or on holiday(s). A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), if required. a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC System iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment ix. Monitoring children for abnormal amperes, voltages, frequ	Х.	The equipment operational observation shall be recorded at suitable intervals
out by the Service Provider who will immediately convey any abnormality in HVAC Plant and Allied Equipment, as well as make immediate arrangements to set right such abnormalities. xii. The Service Provider shall attend maintenance or repair work of the HVAC plant and Allied Equipment on priority basis and if required the maintenance services for rectification of equipment may be provided after office hours or on holiday(s) to set right the service, or at any time due to exigencies/ cmergencies and will provide services for smooth working in the minimum possible time. The Service Provider shall inform the Client well in advance about any maintenance/repair/service work scheduled to be done by the Service Provider after office hours or on holiday(s). A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), if required. a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC System iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment ix. Monitoring children for abnormal amperes, voltages, frequ	xi.	A complete daily general Monitoring of the entire installation shall be carried
HVAĆ Plant and Allied Equipment, as well as make immediate arrangements to set right such abnormalities. xii. The Service Provider shall attend maintenance or repair work of the HVAĆ plant and Allied Equipment on priority basis and if required the maintenance services for rectification of equipment may be provided after office hours or on holiday(s) to set right the service, or at any time due to exigencies/ emergencies and will provide services for smooth working in the minimum possible time. The Service Provider shall inform the Client well in advance about any maintenance/repair/service work scheduled to be done by the Service Provider after office hours or on holiday(s). XIII. A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), if required. a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition. vi. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary iv. Monitoring system for abnormal amperes, voltages, f		
set right such abnormalities. Xii. The Service Provider shall attend maintenance or repair work of the HVAC plant and Allied Equipment on priority basis and if required the maintenance services for rectification of equipment may be provided after office hours or on holiday(s) to set right the service, or at any time due to exigencies/ emergencies and will provide services for smooth working in the minimum possible time. The Service Provider shall inform the Client well in advance about any maintenance/repair/service work scheduled to be done by the Service Provider after office hours or on holiday(s). Xiii. A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), it required. 3. Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment ix. Monitoring system for abnormal amperes, voltages, frequency, nois		
xii. The Service Provider shall attend maintenance or repair work of the HVAC plant and Allied Equipment on priority basis and if required the maintenance services for rectification of equipment may be provided after office hours or on holiday(s) to set right the service, or at any time due to exigencies/ emergencies and will provide services for smooth working in the minimum possible time. The Service Provider shall inform the Client well in advance about any maintenance/repair/service work scheduled to be done by the Service Provider after office hours or on holiday(s). Xiii. A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), it required. 3 Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations vi. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment (and the proper maintenance and whenever necessary ix. Monitoring system for abnormal amperes, voltages		<u></u>
services for rectification of equipment may be provided after office hours or on holiday(s) to set right the service, or at any time due to exigencies/ emergencies and will provide services for smooth working in the minimum possible time. The Service Provider shall inform the Client well in advance about any maintenance/repair/service work scheduled to be done by the Service Provider after office hours or on holiday(s). Xiii. A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), if required. a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation. iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. Vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring the liters for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition.	xii.	The Service Provider shall attend maintenance or repair work of the HVAC
holiday(s) to set right the service, or at any time due to exigencies/ emergencies and will provide services for smooth working in the minimum possible time. The Service Provider shall inform the Client well in advance about any maintenance/repair/service work scheduled to be done by the Service Provider after office hours or on holiday(s). Xiii. A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), if required. a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. Vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. X. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps , Motors, AHU's, F		plant and Allied Equipment on priority basis and if required the maintenance
and will provide services for smooth working in the minimum possible time. The Service Provider shall inform the Client well in advance about any maintenance/repair/service work scheduled to be done by the Service Provider after office hours or on holiday(s). XIII. A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), if required. 3. Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps , Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) men		services for rectification of equipment may be provided after office hours or on
The Service Provider shall inform the Client well in advance about any maintenance/repair/service work scheduled to be done by the Service Provider after office hours or on holiday(s). xiii. A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), if required. a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation, and rectifying the same to facilitate smooth and uninterrupted operation, and rectifying the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) me		
maintenance/repair/service work scheduled to be done by the Service Provider after office hours or on holiday(s). xiii. A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), it required. a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. viii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps , Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and res		
xiii. A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), if required. a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abno		
xiii. A complete safeties monitoring of the HVAC Plant, Allied Equipment and electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), if required. a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abno		
electrical installations shall be carried out by the Service Provider at least once a month during which the defective part(s) shall be replaced by new one(s), if required. a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary iii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abno		
a month during which the defective part(s) shall be replaced by new one(s), if required. a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation and rectifying the same to facilitate smooth and uninterrupted operation iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for	XIII.	
a) Supervisory Services at HVAC Plant and Inside the Building i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary iii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior op		
i. Ensuring that the operation, maintenance and servicing of the entire HVAC System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Ohecking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services of the prior operation for proper smooth services on daily bas		
System is being carried out adequately, smoothly and un-interrupted. ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily basis	a) Sup	
ii. Inspecting HVAC and its allied components and equipment as well as inside the building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily basis	i.	Ensuring that the operation, maintenance and servicing of the entire HVAC
building for ensuring the integrity of the HVAC system whilst being operated and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily basis		
and immediately attending to faults and defects in components or operation, and rectifying the same to facilitate smooth and uninterrupted operation iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps , Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary iii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services on daily basis	ii.	Inspecting HVAC and its allied components and equipment as well as inside the
and rectifying the same to facilitate smooth and uninterrupted operation iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary iii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services of daily basis		
Dealing with any emergency-like situations and taking proper measures in resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services described to the part of the plant for proper smooth services on daily basis		
resolving the issues that crop up during the operation, servicing and maintenance of the HVAC system iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily basis		
iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services described to the prior operation for proper smooth services on daily basis	iii.	
iv. Supervision of activities and liaison with the Client's staff in emergency situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily basis		
situations v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services described to the		
v. Supervision of inspection and maintenance activities necessary to maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary iii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily basis	IV.	
maintain/repair all equipment in trouble-free and smooth operating condition vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily (Sign and Stamp)	17	
vi. Continuous and uninterrupted service for ensuring proper maintenance and uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary iii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services described to the plant f	٧.	
uninterrupted supply of air through air vents and ducts. vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services described in the proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services described in the proper s		
vii. Carrying out routine maintenance and making sure all electrical systems are operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services described in the proper smooth services	V 1.	•
operating normally for the equipment viii. Attending to phone calls and responding as necessary ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services described by the plant for proper smooth services are plant for proper smooth services are	:	
ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services day (Sign and Stamp)	VII.	
ix. Monitoring system for abnormal amperes, voltages, frequency, noise, vibration or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily		
or any other abnormal condition. x. Reporting to Client and Calling for external help in emergency situations and whenever necessary b) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily manufacture.		
x. Reporting to Client and Calling for external help in emergency situations and whenever necessary D) Operation Services at Chillers, Pumps, Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services displayed to the plant for proper smooth services displ	ix.	
whenever necessary D) Operation Services at Chillers, Pumps , Motors, AHU's, FCU's, cooling Towers and Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services described in the proper smooth services described in the plant for proper smooth serv		
Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services displayed. (Sign and Stamp)	х.	
Allied Piping: In addition to, and concurrent with, a) mentioned above, following services: i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily [Sign and Stamp]	o) Oner:	
i. Attending to phone calls and responding as necessary ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily (Sign and Stamp)		
ii. Maintain and operate Chillers and its allied equipment (Cooling towers, Pumps, Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services day (Sign and Stamp)		
Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily (Sign and Stamp)	i.	Attending to phone calls and responding as necessary
Motors, Air handling units, Fan coil units, valves and allied piping) iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily (Sign and Stamp)	ii	Maintain and operate Chillers and its allied equipment (Cooling towers Dumns
iii. Monitoring chillers for abnormal temperature, pressure, noise, vibration or any other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily (Sign and Stamp) For Bank Stampo)	11.	
other abnormal condition iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily (Sign and Stamp) For Bank Checking Sign of all sensors, fluids, gases and other values prior operation for proper smooth services daily (Sign and Stamp)	iii.	
iv. Checking and testing of all sensors, fluids, gases and other values prior operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services daily (Sign and Stamp) For Bank Convents (2015)	111.	
operation for proper smooth services on daily basis v. Checking and testing the Plant for proper smooth services deliver (Sign and Stamp) For Bank Stamp)	iv.	Checking and testing of all sensors, fluids, gases and other values prior
v. Checking and testing the Plant for proper smooth services de Civil (Sign and Stamp) For Ban (Supremote Sarre)	-	
(Sign and Stamp) For Ban (Survivo)	V.	
(Sign and Stamp) For Ban (Signson) Samp)		
	(Sign and Sta	11 St manuscrave All

Page **35** of **66** HOK-M-93

vii. Supervision of inspection and maintenance activities mentioned below necessary to maintain the HVAC system in trouble-free and smooth operating condition. viii. Reporting to Service Provider's supervisor or calling for external help in emergency situations and to report faulty parts or abnormal running condition. ix. Cleaning the HVAC Plant along with disposal of waste x. Immediately attending to faults and defects in components or continuous services, and rectifying the same to facilitate smooth and uninterrupted services. xi. Troubleshooting in case of defects, abnormal conditions and complaints. Calling for backup support if necessary to further troubleshoot and rectify the malfunction. c) Electrical Services:: In addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center, apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c).		I
necessary to maintain the HVAC system in trouble-free and smooth operating condition. Viii. Reporting to Service Provider's supervisor or calling for external help in emergency situations and to report faulty parts or abnormal running condition. ix. Cleaning the HVAC Plant along with disposal of waste X. Immediately attending to faults and defects in components or continuous services, and rectifying the same to facilitate smooth and uninterrupted services. Xi. Troubleshooting in case of defects, abnormal conditions and complaints. Calling for backup support if necessary to further troubleshoot and rectify the malfunction. C) Electrical Services: In addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center, apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in painting of all equipment exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in painting of all equipment exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in painting of all		Immediate attending of Chillers and allied equipment in case of emergency
condition. Reporting to Service Provider's supervisor or calling for external help in emergency situations and to report faulty parts or abnormal running condition. ix. Cleaning the HVAC Plant along with disposal of waste X. Immediately attending to faults and defects in components or continuous services, and rectifying the same to facilitate smooth and uninterrupted services. Xi. Troubleshooting in case of defects, abnormal conditions and complaints. Calling for backup support if necessary to further troubleshoot and rectify the malfunction. Cl Electrical Services: In addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center, apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. Providing assistance in painting of all equipment, exposed ducting and piping if the clock support is required for the following services: i. Provide assistance in in addition to, and concurrent with above a & b,c & d Round the clock support is required for the following service	vii.	
iii. Pealing to Service Provider's supervisor or calling for external help in emergency situations and to report faulty parts or abnormal running condition. ix. Cleaning the HVAC Plant along with disposal of waste. x. Immediately attending to faults and defects in components or continuous services, and rectifying the same to facilitate smooth and uninterrupted services. xi. Troubleshooting in case of defects, abnormal conditions and complaints. Calling for backup support if necessary to further troubleshoot and rectify the malfunction. c) Electrical Services: In addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center , apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in mergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in the original painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concu		
emergency situations and to report faulty parts or abnormal running condition. ix. Cleaning the HVAC Plant along with disposal of waste x. Immediately attending to faults and defects in components or continuous services, and rectifying the same to facilitate smooth and uninterrupted services. xi. Troubleshooting in case of defects, abnormal conditions and complaints. Calling for backup support if necessary to further troubleshoot and rectify the malfunction. c) Electrical Services: In addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant is. esystem including all electric panels, sub panels, DBs, motor control center, apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in painting of all equipment exposed ducting and piping if the original paint has been scratched, or has deteriorated. Provide assistance in mainting of all equipment of the provider assistance in emergency situations ii. Provide assistance in forting the providers of the equipment of the provider's supervisory staff. vi. Smooth		
ix. Cleaning the HVAC Plant along with disposal of waste x. Immediately attending to faults and defects in components or continuous services, and rectifying the same to facilitate smooth and uninterrupted services. xi. Troubleshooting in case of defects, abnormal conditions and complaints. Calling for backup support if necessary to further troubleshoot and rectify the malfunction. c) Electrical Services: In addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center , apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. iii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. Provide assistance in memergency situations iii. Provide assistance in memergency situations iii. Provide assistance in memergency situations iii. Provide assistance in following services: i. Provide assistance in following services: i. Provide assistance in following services: ii. P	viii.	
x. Immediately attending to faults and defects in components or continuous services, and rectifying the same to facilitate smooth and uninterrupted services. xi. Troubleshooting in case of defects, abnormal conditions and complaints. Calling for backup support if necessary to further troubleshoot and rectify the malfunction. c) Electrical Services: In addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant it. es system including all electric panels, sub panels, DBs, motor control center, apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in mergency situations		
services. xi. Troubleshooting in case of defects, abnormal conditions and complaints. Calling for backup support if necessary to further troubleshoot and rectify the malfunction. c) Electrical Services: In addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center , apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in mergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. Smooth and uninterrupted services through periodical inspections and monitoring. V. Resolution of fault of plants and allied equipment Vi. Going	lX.	Cleaning the HVAC Plant along with disposal of waste
services. xi. Troubleshooting in case of defects, abnormal conditions and complaints. Calling for backup support if necessary to further troubleshoot and rectify the malfunction. c) Electrical Services: In addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center , apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). iii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in painting of all equipment with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in incomplete services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii.	X.	Immediately attending to faults and defects in components or continuous
services. xi. Troubleshooting in case of defects, abnormal conditions and complaints. Calling for backup support if necessary to further troubleshoot and rectify the malfunction. c) Electrical Services: In addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center, apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other	211	
Troubleshooting in case of defects, abnormal conditions and complaints. Calling for backup support if necessary to further troubleshoot and rectify the malfunction. C. Electrical Services:: In addition to, and concurrent with, (a) (b) above, the Services roughly an electric system for HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center , apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of all equipment, exposed ducting and piping if the clock support services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in painting of all educences, Pumps, pipelines etc. Provide assistance in painting of all electrical & mechanical components of the equipment. Osing off-site to bring in parts, material, documents or consumables as instructed by Service Provider'		
for backup support if necessary to further troubleshoot and rectify the malfunction. c) Electrical Services: In addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant ie. system including all electric panels, sub panels, DBs, motor control center, apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Provide assistance in painting of all equipment with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in problems of all devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round	xi.	
malfunction. C) Electrical Services: in addition to, and concurrent with, (a) (b) above, the Service Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center , apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumable		for backup support if necessary to further troubleshoot and rectify the
Provider qualified services at the HVAC Plant Room for: i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center , apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. 1) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. 2) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in painting of all equipment or consumables as instructed by Service Provider's supervisory staff. vi. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower		
i. Smooth operation as well as adequate servicing and maintenance of Complete electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center , apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water syste	-	
electric system for HVAC Plant i.e. system including all electric panels, sub panels, DBs, motor control center , apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. ii. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). iii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iiii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in troubleshooting or repair and rectification work. iii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Mashing & cleaning of air filters. Flushing and cleaning of air filters		
panels, DBs, motor control center apparatus control panel, power control wiring electric Switch gear of HVAC system including earthing system. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: ii. Provide assistance in meergency situations iii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room.	i.	
wiring electric Switch gear of HVAC system including earthing system. Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
Dealing with any emergency-like situations and taking proper measures in resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. Providing assistance in painting of air devices, Pumps, pipelines etc. Provide assistance in addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: Provide assistance in troubleshooting or repair and rectification work. Carry spare parts, tools or documentation between work sites. V. Smooth and uninterrupted services through periodical inspections and monitoring. V. Resolution of fault of plants and allied equipment Vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. Vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
resolving the issues that appear during the operation, servicing and maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
maintenance of the HVAC plants iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). iii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	11.	
iii. The checkup of wiring, thermostat controls etc. outside and inside the building shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). iii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
shall also be ensured and properly maintained and serviced. d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). iii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iiii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in emergency situations iii. Provide assistance in troubleshooting or repair and rectification work. iiii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	;;;	
d) Technical Assistance Services: In addition to, and concurrent with, (a) (b) (c) above, the following services at the HVAC Plant Room and inside the building for: i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	111.	
i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	d) Technic	
i. Providing required assistance in conducting the operation, maintenance and servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. Providing assistance in painting of air devices, Pumps, pipelines etc. Providing assistance in painting of air devices, Pumps, pipelines etc. Providing assistance in addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	-	
servicing of the HVAC system mentioned above in (a) (b) (c). ii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
iii. Providing assistance in painting of all equipment, exposed ducting and piping if the original paint has been scratched, or has deteriorated. iii. Providing assistance in painting of air devices, Pumps, pipelines etc. e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
the original paint has been scratched, or has deteriorated. Providing assistance in painting of air devices, Pumps, pipelines etc. Providing assistance in painting of air devices, Pumps, pipelines etc. Provide assistance in addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: Provide assistance in emergency situations Carry spare parts, tools or documentation between work sites. Smooth and uninterrupted services through periodical inspections and monitoring. V. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	ii.	Providing assistance in painting of all equipment, exposed ducting and piping if
e) Technical Support Services: In addition to, and concurrent with above a & b,c & d Round the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	iii.	Providing assistance in painting of air devices, Pumps, pipelines etc.
the clock support is required for the following services: i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	e) Technic	
i. Provide assistance in emergency situations ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	-	
ii. Provide assistance in troubleshooting or repair and rectification work. iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
iii. Carry spare parts, tools or documentation between work sites. iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
iv. Smooth and uninterrupted services through periodical inspections and monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
monitoring. v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
v. Resolution of fault of plants and allied equipment vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	141	
vi. Going off-site to bring in parts, material, documents or consumables as instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	V.	
instructed by Service Provider's supervisory staff. vii. Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
Any other work assigned by the Client Frequency of Services for Plant Operations Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	vii.	
Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	7 441	sacration and an end of the officer
Check for the working of all electrical & mechanical components of the equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	Freguency	of Services for Plant Operations
equipment. Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.	requericy	
Dosing of chemical for treatment of cooling tower and chiller feed water system. Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
Maintain log sheets/log book for daily operation. Any service or running repairs required during the operation of the plant. Cleaning of the equipment machinery and complete Plant Room. Washing & cleaning of air filters. Flushing and cleaning of strainers.		
Washing & cleaning of air filters. Flushing and cleaning of strainers. Flushing and cleaning of strainers.	ଧ	
Washing & cleaning of air filters. Flushing and cleaning of strainers. Flushing and cleaning of strainers.	ξi ξi	
Washing & cleaning of air filters. Flushing and cleaning of strainers. Flushing and cleaning of strainers.	Dai Ser	
Flushing and cleaning of strainers.		Lieaning of the equipment machinery and complete Plant Room.
Trushing and creating of strainers.	M K K K K K K K K K K K K K K K K K K K	
1 A HANNEY AND		Flushing and cleaning of strainers.
(Sign and Stamp) For Bank (Signward Stamp)		1 a usuvi vaure A.V
	(Sign and Stam)	For Bank (Status)

HOK-M-93 Page **36** of **66**

	Service of automatic and safety controls of equipment and system	
	Checking of oil and other lubricant levels and changing.	
	Checking of belt driven equipment and adjustment of belt tension and	
	alignment	
	Checking of water levels and controls valves.	
	Changing of parts due to normal wear and tear when necessary	
Checking and adjustment of all pressure and safety devices.		
	Adjustment and lubrication/ greasing of bearings & glands of equipment.	
	Annual Maintenance work to be carried out one by one on chillers from	
	December 15 to February 15 or as weather situation or instruction by the Client	
le [Parts to be changed where necessary	
Annually Service	Instruction given in the Manufacturer's Manuals to be followed. Record of	
	various checks and tests to be maintained for further reference.	
A S	A satisfactory report on annual maintenance will be provided to the Client	

Frequency	y of Services for Chillers (Gas/Steam and Electrical)
	Complete over all visual and general inspection of the chillers
	Startup of the chillers.
	Maintaining the daily data log sheets for the chiller operation for
	temperatures, pressures, levels etc.
	Vacuuming / purging of the chillers as per requirement
	Checking of Gas Pressure
	Checking LiBr solution level of chiller
	Checking operation of burners with safeties
	Maintaining chilled water outlet temperature as per requirement through
	chiller operation
	Checking and monitoring of the chiller pumps such as Refrigerant pump,
	Solution pump, Purge pump etc. Chagling of all safeting
	Checking of all safeties Checking water/refrigerant level of chiller
	Monitor Set Points of the HVAC system
	Monitor for the working of all electrical & mechanical components of the
	equipment.
	Any service or running repairs required during the services of the HVAC
	System
ଥ	General Upkeep of the equipment machinery and complete HVAC System
Daily Service	Premises.
Ser	Recording continuous and uninterrupted management services of the
X	chiller parameters on hourly basis
Dai	Monitoring the control panel of the chiller from dust and other external
	material which could be harmful for chiller controls
	Checking of Burner
	Checking Amperes, Performance and Abnormality of Absorber Pump,
	Refrigerant Pump, Vacuum Pump Confirmation of setting values of safety devices and control devices
	Checking of programming of Microprocessor.
	Refrigerant Blow down (If necessary)
9	
	Checking of all i.e. Temperature, Pressure, Fluid level etc.
er	Checking of alcohol(if required, Alcohol will be provided by Client)
Monthly Servi	Checking of all safeties
1th	Checking LiBr solution level of chiller
10 <u>1</u>	Checking refrigerant level of chiller
리	Checking operation of burners with safeties

For Ban PARIMEN

HOK-M-93 Page **37** of **66**

Cleaning of Condenser fins if required Monitor Set Points and safety cutouts of HVAC system. Monitor the HVAC system for refrigerant or Oil leakage. Flushing and cleaning of strainers. Monitoring of Valves for normal working. Inspection & Service of automatic and safety controls of HVAC system. Monitoring of oil and other lubricant levels and changing (if required). Changing of parts due to normal wear and tear when necessary. Monitoring and adjustment (if required) of all pressure and safety devices. Adjustment and lubrication/ greasing of bearings & glands etc. of HVAC system Pressure checking of Chiller with N2 (N2 will be provided by the CLIENT) Servicing of Purge Pump Checking & Servicing of Absorbent pump. Checking & Servicing of Refrigerant pump. Servicing of Burner Checking and Servicing of H.T/LT HVAC System Eliminators Servicing of HVAC System Servicing of Suction Port of Burner Checking of Damper Motor of Burner Checking of Burner Flame (Visual Inspection) Checking of Gas Pressure Checking of Diesel Line and associated Tank Checking of Butterfly Valve of Burner Flame Adjustment Adjustment of Air Damper and Gas Damper Servicing of Gas Line Strainer. Servicing of Diesel Line Strainer. Restarting of chiller with observation. Cycle testing of LiBr Solution and submission of Report with detailed analysis Calibration of sensors (if found faulty will inform accordingly) Levelling Electrode Vacuuming Refrigerant Blow down (If necessary). Checking of all Temperatures, Pressures and Fluid level. Confirmation of setting values of safety devices and control devices. Checking of all safety devices and adjustment if required Servicing of control panel Checking programming of Microprocessor Checking and adjustment of Inverter Programming. Checking Amp. and abnormality of Absorber Pump, Refrigerant Pump, Vacuum Pump De-scaling of Absorber and Condenser with De-scalar Neutralization with Neutralizer Brushing with brushing Machine Checking of all safeties **Annually Service** Checking refrigerant and absorbent level of Chiller Checking operation of burners with all safeties Monitoring of Compressor Oil and Recommendation for change if required. Monitoring of Electrical Terminals and tightening of loose connections. Assure that all bearings are lubricated. Monitoring the condition of the motor.

For Ban

HOK-M-93 Page **38** of **66**

Monitoring of Amperes of Pumps.
Monitor and inspection for any abnormal noise
Monitor and adjust Spring Isolators, Changing of the same if required
Monitoring of Glycol of the HVAC system

_	
Frequenc	cy of Services for Cooling Tower
	Complete overall visual inspection to make sure that all equipment is
	operating and that safety systems are in place
	Inspection of Cooling Tower circulating water Circuit
ice	Chemical Dosing
IV	Checking of PH & TDS of cooling water circuit
Se	Checking Ampere of cooling tower motor
Daily Service	Fan Balancing & Adjustment if required
Da	Checking of float valve of cooling towers for proper operation or leakage
	Complete overall visual inspection to make sure that all equipment is
	operating and that safety systems are in place.
	Inspection of Cooling Tower circulating water Circuit.
	Servicing of Hot & Cold Water basin.
	Checking of float valve of cooling towers for proper operation or leakage.
	Checking of motor supports and fan blades.
	Ensure that the strainers at water return sump to chiller are in position and
	clean.
	Ensure that air intake louvers are clear, properly fixed, clean and not
Weekly/ Monthly <u>Service</u>	obstructed.
V. Vic	Ensure that there is no oil leak from the fan gear or bearing box. Ensure that
Ser	Fan-Belts are in good operating condition and belt tension is correct
y/ Iy.	Ensure that the top water basin distribution holes are clear, clean and not
ekl 1th	obstructed.
Vec	Check all globe valves on top basin for proper adjustment for required flow
> 2	GPM.
	Complete overall visual inspection to make sure that all equipment is
	operating and that safety systems are in place.
	Inspection for clogging.
	Checking the condition of Fan Motor.
	Check for loose fills, connections, leaks, etc.
	Check motor supports and fan blades.
ej	De-scaling of Cooling Towers.
	Charging of Water Treatment Chemicals.(Chemicals will be Provided by
Ser	Client)
Annually Servi	Inspections of Cooling Tower circulating water Circuit.
ual	Repairing, if any leakage in the system (Material will be provided by Client).
	Checking of float valve of cooling towers for proper operation or leakage.
4	Ensure fan gear and bearing box is well lubricated.

Frequency of Services for Water Pumps and Motors Set		
41	Checking the condition of the motor.	
Daily Service	Checking and securing of all pump mountings	
ail erv	Checking Amperes of Pumps.	
의 있	Check and inspection for any abnormal noise	
	Overall visual inspection.	
	Assure that all bearings are lubricated.	

For Ban Signweron

HOK-M-93 Page **39** of **66**

	Inspection of bearings, drive, pulley & gland rope. Adjust, repair or replace new material (if required will be provided by Client).			
Checking the condition of the motor.				
	Checking of Amperes of Pumps.			
	Check and inspection for any abnormal noise.			
	Overall visual inspection.			
	Assure that all bearings are lubricated			
l ≱	Inspection of bearings, drive, pulley & gland rope. Adjust, repair or replace (if required will be provided by Client).			
lal ice	Checking the condition of the motor.			
Annually Service	Checking of Amperes of Pumps.			
A %	Check and inspection for any abnormal noise			

Checking of any abnormality in normal operation condition. Checking & Servicing of Filters. Humidity control Checking of Coil's condition. Checking of Blowers and housing. Checking of the drain pan for smooth and proper flow of condensate. Overall Visual Inspection Checking & Servicing of Filters. Inspection of Fan & Fan motor Checking of Blowers, belts and Temperature, Dampers, Valves & Pressure Gauges. Checking of the drive motor. Checking of the drive and driven pulley alignment. Checking of the drain pan for smooth and proper flow of condensate Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the electrical connections of the AHU Drive Motor that these completely tightened grounded and insulated.	Frequenc	y of Services for AHU
Overall Visual Inspection Checking & Servicing of Filters. Inspection of Fan & Fan motor Checking of Blowers, belts and Temperature, Dampers, Valves & Pressure Gauges. Checking of the drive motor. Checking of the drive and driven pulley alignment. Checking of the drain pan for smooth and proper flow of condensate Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	al	Checking of any abnormality in normal operation condition.
Overall Visual Inspection Checking & Servicing of Filters. Inspection of Fan & Fan motor Checking of Blowers, belts and Temperature, Dampers, Valves & Pressure Gauges. Checking of the drive motor. Checking of the drive and driven pulley alignment. Checking of the drain pan for smooth and proper flow of condensate Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	/ice	Checking & Servicing of Filters.
Overall Visual Inspection Checking & Servicing of Filters. Inspection of Fan & Fan motor Checking of Blowers, belts and Temperature, Dampers, Valves & Pressure Gauges. Checking of the drive motor. Checking of the drive and driven pulley alignment. Checking of the drain pan for smooth and proper flow of condensate Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	er	y .
Overall Visual Inspection Checking & Servicing of Filters. Inspection of Fan & Fan motor Checking of Blowers, belts and Temperature, Dampers, Valves & Pressure Gauges. Checking of the drive motor. Checking of the drive and driven pulley alignment. Checking of the drain pan for smooth and proper flow of condensate Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	N S	
Overall Visual Inspection Checking & Servicing of Filters. Inspection of Fan & Fan motor Checking of Blowers, belts and Temperature, Dampers, Valves & Pressure Gauges. Checking of the drive motor. Checking of the drive and driven pulley alignment. Checking of the drain pan for smooth and proper flow of condensate Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	ail	Checking of Blowers and housing.
Checking & Servicing of Filters. Inspection of Fan & Fan motor Checking of Blowers, belts and Temperature, Dampers, Valves & Pressure Gauges. Checking of the drive motor. Checking of the drive and driven pulley alignment. Checking of the drain pan for smooth and proper flow of condensate Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these		Checking of the drain pan for smooth and proper flow of condensate.
Inspection of Fan & Fan motor Checking of Blowers, belts and Temperature, Dampers, Valves & Pressure Gauges. Checking of the drive motor. Checking of the drive and driven pulley alignment. Checking of the drain pan for smooth and proper flow of condensate Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these		Overall Visual Inspection
Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	401	Checking & Servicing of Filters.
Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	rice	Inspection of Fan & Fan motor
Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	er.	Checking of Blowers, belts and Temperature, Dampers, Valves & Pressure
Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	NS V	Gauges.
Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	kly th	Checking of the drive motor.
Overall Visual Inspection Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	ee] onj	Checking of the drive and driven pulley alignment.
Checking of Coil's condition. Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these	≥ ≥	Checking of the drain pan for smooth and proper flow of condensate
Inspection of Fan & Fan motor. Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these		Overall Visual Inspection
Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these		Checking of Coil's condition.
Checking of Blowers, belts and Temperature & Pressure Gauges. Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these completely tightened grounded and insulated.	9	Inspection of Fan & Fan motor.
Greasing of bolts & Motors. (upon requirement) Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these completely tightened grounded and insulated.	Ķ	Checking of Blowers, belts and Temperature & Pressure Gauges.
Servicing of Coils. (upon requirement) Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these completely tightened grounded and insulated.	Ser	Greasing of bolts & Motors. (upon requirement)
Checking of the pipe work, pipe insulation Checking of the electrical connections of the AHU Drive Motor that these completely tightened grounded and insulated.	<u> </u>	Servicing of Coils. (upon requirement)
Checking of the electrical connections of the AHU Drive Motor that these completely tightened grounded and insulated.	<u>ual</u>	Checking of the pipe work, pipe insulation
	Ann	Checking of the electrical connections of the AHU Drive Motor that these completely tightened grounded and insulated.

Frequency of Services for Fan Coil Units: The Fan Coil Units shall be maintained and Operated based on the following regular checks and inspections.

Checking the drive motor for proper operation, amps drawn, voltage etc.

Checking of the Blower

Checking of the cooling coil

Checking of pipe work and pipe insulation

Checking of valves, strainers,

Checking of filters checking of controls, motorized valve, thermostat

Checking of the drain pan for smooth flow of condensate

Checking the noise level

Checking the abnormal vibration.

Frequency of Services for Electrical Motors & Starters: The Electrical Motors & Starters shall be maintained and Operated based on the following regular checks and inspections.

For Bank Signwand

HOK-M-93 Page **40** of **66**

Cleaning, servicing and checking of all components.

Tightening of wire/Cable connections.

Cleaning & adjustment of contacts.

Checking of earthing

Checking of motor winding insulation.

Replacement of bearings (if needed)

Frequency of Services for Electric Control Panels: The Electric Control Panels shall be maintained and Operated based on the following regular checks and inspections.

Checking and services of MCCB's, disconnect switches, fuses contacts, relays, and overloads, cutouts & other safety devices.

Tightening of wiring connections.

Checking of wiring insulation

Checking of earthing

Frequency of Services for Air Distribution Systems: The Air Distribution Systems shall be maintained and Operated based on the following regular checks and inspections.

Cleaning of air devices

Repairs of exposed ducts, duct insulation, jacketing and covering

Frequency of Services for Piping Systems: The Piping Systems shall be maintained and Operated based on the following regular checks and inspections.

Cleaning and flushing of all piping systems including chemical cleaning when

Servicing and cleaning of all valves, strainers on requirement Basis

Repair of insulation, jacketing and covering of all insulated piping.

5. Tools & Equipment (T&E) for Execution of Services

The Service Provider shall bring and maintain all necessary T&E at site which are required for execution of services under the Contract. During pendency of the Contract, if Client finds that the T&E brought by the Service Provider is not sufficient and as per desired quality, the Service Provider shall immediately replace and/or bring/arrange additional T&E for smooth execution of services without any additional cost. Such T&E shall include but not limited to testing and diagnostic instruments if required. In case of failure to arrange and maintain the necessary T&E, Client reserve the right to take punitive action as per the Contract which includes and is not limited to imposition of liquidity damages, termination of contract and forfeiture of Performance Security."



HOK-M-93 Page **41** of **66**

SCHEDULE D TO BID

Services to be performed by Sub-Service Providers

 Sub-Contracting is not allowed	

HOK-M-93 Page **42** of **66**

SCHEDULE E TO BID

PROPOSED METHODOLOGY/ PROGRAM OF PERFORMING THE SERVICES

As a part of Technical Proposal and in accordance with Schedule of Approximate Areas for Services and frequency, bidder shall provide a complete program of services with proposed resources deployment as per the table below;

1. Resources:

Sr No	Nature of Service	Execution Schedule	Services Execution Management Plan
1.	Supervisory Services at both HVAC Plants and inside the Building		
2.	Technical Operation Services at Chillers and Allied Equipment (BSC House)	Monday to Saturday from	
3.	Technical Operation Services at Chillers and Allied Equipment (Third Floor)	07:30AM to 06:30PM	
4.	Technical Assistance Services		
5.	Technical Support Services including Troubleshooting, Inspections, Preventive and Corrective Services for HVAC system and Allied Equipment	As per preventive and corrective maintenance requirement and requirements shared by Client (including Weekends and Holidays)	Round the clock 365 days a year

HOK-M-93 Page **43** of **66**

SCHEDULE D TO BID

Services to be performed by Sub-Service Providers

 Sub-Contracting is not allowed
3

HOK-M-93 Page **44** of **66**

(Bidding Documents-Section-VI-Part-2)

Section VI - CONDITIONS OF CONTRACT



HOK-M-93 Page **45** of **66**

A. GENERAL CONDITIONS OF CONTRACT (GCC)

1. General Provisions

1.1. Definitions

- 1.1.1. Unless the context otherwise requires, the following terms whenever used in this Contract have the following meanings:
 - a) "Applicable Law" means the laws and any other instruments having the force of law in the Islamic Republic of Pakistan.
 - b) "Authorized Officer" means the person notified by SBP BSC to act as the officer in-charge for the purpose of the implementation of Contract and named as such in the Work Order or Letter of Acceptance.
 - c) "Confidential Information" means all information (including copies" however disclosed including any Intellectual Property Rights (IPR), documents, ideas, computer programs, specifications, plans, drawings, pricing, marketing and customer information, information relating to market opportunities or business affairs and any other information marked or by implication, confidential or of commercial value.
 - d) "Client / SBP BSC" means SBP Banking Services Corporation, that signs the Contract for the Services with the selected Service Provider.
 - e) <u>"Contract"</u> means the legally binding written agreement signed between the Client and the Service Provider, which includes all the attachments and appendices thereto, and all documents incorporated by reference therein.
 - f) "Day" means a Gregorian calendar day unless indicated otherwise.
 - g) "GCC" means these General Conditions of Contract;
 - h) "Government" means the Government of the Islamic Republic of Pakistan;
 - i) "Party" means the Client or the Service Provider, as the case may be, and "Parties" means both of them;
 - j) **"Services"** means the work to be performed by the Service Provider under this Contract.
 - k) "Service Provider's Bid" means the completed Bidding Documents submitted by the Service Provider to the Client
 - l) **"SCC"** means the Special Conditions of Contract by which the GCC may be amended or supplemented;
 - m) "Specifications" means the specifications of the service included in the Bidding Documents submitted by the Service Provider to the Client
 - n) **"Service Points"** are the number of locations of services where service provider is required to provide uninterrupted services, simultaneously.
 - o) "Service Provider" means the person whose tender/bid has been accepted by the Client and the legal successors in title to such person, but not (except with the consent of the Employer) any assignee of such person.
 - p) "Service Provider's Employee" employe

HOK-M-93 Page **46** of **66**

	Service Provider.
	Scrvice rroviuer.
1.2. Applicable Law	1.2.1. The Contract shall be governed by the laws of the Islamic Republic of Pakistan.
1.3. Language	1.3.1. This Contract has been executed in English/Urdu, which shall be the binding and controlling language for all matters relating to the meaning or interpretation of this Contract
1.4. Notices	1.4.1. Any notice, request, or consent made under this Contract
	shall be in writing and shall be deemed to have been made when delivered in person to an authorized representative of the Party to whom the communication is addressed, or when sent by registered mail, email, or facsimile to such Party at the address specified in the SCC.
1.5. Location	1.5.1. The Services shall be performed at such locations as are
	specified in at Section VI-Part-1 .and, where the location of a particular task is not so specified, at such locations in
	Pakistan, as the Client may approve.
1.6. Authorized	1.6.1. Any action required or permitted to be taken, and any
Representatives	document required or permitted to be executed, under this Contract by the Client or the Service Provider may be taken or executed by the officials specified in the SCC.
1.7. Instructions,	1.7.1. The Service Provider shall carry out all instructions of SBP
,Inspection and	BSC communicated through the authorized person which
Audit by the Client	comply with the applicable laws where the Buildings/ Premises are located.
	1.7.2. The Service Provider shall upon reasonable notice by the
	Client allow the Client's Management, its auditors to inspect, examine and audit its accounts and records which are directly relevant to the performance of the Services as outlined in this contract and to have them audited by auditors appointed by the Client if so required by the Client.
1.8. Taxes, Duties	1.8.1. The Service Provider shall organize to pay its own and its
and other	employees taxes, and the Client is authorized to withhold
applicable laws	any tax from payment to the Service Provider and to deposit the same into the Governmental Treasury. The Service Provider shall also ensure compliance with local laws and applicable regulations.
	1.8.2. Any additional tax, levies, duties, or modification in the
	existing rates of tax and other applicable laws imposed during the pendency of this contract shall be adjusted in the
	contract price by both parties.
1.9. Priority of	1.9.1. The Contract and Documents are to be taken as mutually
Contract Documents	explanatory. Ambiguities or discrepancies between the documents shall be promptly brought to the attention of
Documents	SBP BSC for clarification. In case of conflict between the
	documents, the most stringent requirement shall be deemed
1.10. Services	to be included in the Contract as determined by SBP BSC. 1.10.1.The Services include as mentioned in bidding documents
1.10. Services	and in accordance with Client's requirements, industry best
	practices.
1.11. Service	1.11.1.The Services Provider shall provide and ensure
Execution Schedule	uninterrupted services as per Scope of Services. Client however, reserves the right to make adjustments.
	alterations in the service timings depending upon the

For Ban Signivision

HOK-M-93 Page **47** of **66**

	T
	requirements of the Client which will be communicated to the Service Provider from time to time. 1.11.2. The Services Provider shall be obliged to complete the Services as assigned under the Contract during the service schedule fixed by the Client and if the Service Provider has to spend time beyond the assigned service schedule to complete the contractual obligation, the Client shall not be responsible for any extra payment. 1.11.3. If required on holidays, the Service Provider shall be obliged to manage the Services in such a manner as necessary for the execution of the Services under the Contract. If the Service Provider fails to provide the requisite services, Client is entitled to impose Liquidated Damages as per clause – 3.11. 1.11.4. The Service Provider shall have to coordinate with the authorized officer of the Client in advance if he wants to execute the services beyond the services schedule to perform his contractual obligations under the Contract. 1.11.5. If, for any reason beyond the reasonable control of the Service Provider, it becomes necessary to replace any of its representative, the Service Provider shall provide as a replacement after fulfillment of requirements as per Client's security protocol/requirement. 1.11.6. If Client finds that any of the Service Provider's representative have (i) committed serious misconduct or have been charged with having committed a criminal action, or (ii) have reasonable cause to be dissatisfied with the performance of any of any of its employees, then the Service Provider and the Service Provider's representative have (i) committed serious misconduct or have been charged with having committed a criminal action, or (ii) have reasonable cause to be dissatisfied with the performance of any of any of its employees, then the Service
1.12. Attendance of Meetings	Provider shall, arrange for a replacement. 1.12.1. The Service Provider shall attend all the meetings, when called by Client, to discuss the quality of services and other matters related to the Contract, without any compensation from Client
1.13. Responsibilities, Liabilities And Warranties By The Service Provider	Notwithstanding to any provision contained in the Contract, the Service Provider shall be exclusively responsible for the following during the currency of the Contract: 1.13.1 The Service Provider shall execute and deliver Services as mentioned in the Contract in accordance with Client's requirements, relevant rules, regulations, standards, safety measures and shall maintain good order at the premises as communicated by Client from time to time during execution of the services. The Services shall be fit for the express or implied purposes for which supplied. 1.13.2 Service Provider shall follow professional official etiquette, industry best practices and adequate standards of hygiene while executing the services like avoidance of abusive language by its employees, ensure proper dressing/uniform as per local culture/norms by displaying service providers cards for identification and any others practices which are followed in Client. Service Provider shall not act in a way which is prejudicial to Client's interests or business;

For Ban PARIMEN

HOK-M-93 Page **48** of **66**

1.13.3	The Service Provider/or their resources to hold requisite
	power, authority and valid license and authority to carry
	out the Contract and deliver Services mentioned In the
	Contract. The Service Provider shall obtain or renew all
	permits, NOCs, licenses, certificates or registrations etc.
	that may be required to perform the Services under this
	Contract.
1.13.4	The Service Provider shall bring at site all equipment
	including but not limited to those specified in the Contract
	necessary to carry out the services under the Contract. The
	Service Provider shall ensure the equipment remain in
	working order.
1.13.5	The Service Provider shall adhere to all directions of Client
	and observe security protocol as per Client's requirement
	for execution of services like security clearance of its
	employees, etc. for which documents / data shall also be
	provided to Client. The Service Provider warrants that its
	employee(s) have no criminal record and shall not indulge
	in any criminal activity. The Service Provider agrees that if
	Client is not satisfied with the services of its resources for
	execution of services, necessary replacements will be
	arranged and Client shall have exclusive right to not accept
	the services of any service provider resource.
1.13.6	Any breach by Service Provider of this Clause, shall
	constitutes a material breach of the Contract and may lead
	towards Termination as per Clause-2.6.2 In addition, Client
	shall be entitled to require Service Provider to (a) remedy
	the breach at its cost; (b) pay for it to be remedied; or (c)
	repay all amounts already paid for the defective Services.

2. Commencement, Completion, Modification, and Termination of Contract		
2.1. Effectiveness	2.1.1.	This Contract shall come into effect on the date the Contract is
of Contract		signed by both parties or such date as may be stated in the SCC
		or work order.
2.2. Duration of	2.2.1.	The duration of this contract shall be twelve (12) months,
Contract		renewable for further two years on mutual consent on the same
		rates, terms and conditions subject to clause 5.2 or any other
		clause of this Contract.
2.3. Extension of	2.3.1.	The Contract may further be extended on same rates, terms and
Contract		conditions (subject to clause 5.2 or any other clause of this
		Contract) for a period suitable to SBP BSC to call new tenders
		and award of a fresh contract.
2.4. Modification/	2.4.1.	Modification of the terms and conditions of this Contract,
Variations		including any modification of the scope of the Services or the
		Contract Price, may only be made by written agreement
		between the Parties in compliance with PPR-2004.
2.5. Force	2.5.1.	Definition
Majeure		For this Contract, "Force Majeure" means an event that is
,		beyond the reasonable control of a Party and which makes a
		Party's performance of its obligations under the Contract
		impossible or so impractical as to be considered in books.
		under the circumstances. The Party affected by Force Majeure
		CIVIL E
For Bidder (Sign and Stamp)		For Bank Signer Samo
		PARIMENT

HOK-M-93 Page **49** of **66**

shall on the occurrence of the event leading to Force Majeure immediately notify the other Party in writing and take all reasonable steps to overcome the Force Majeure. If the Force Majeure persists the affected Party may terminate this contract as per **clause 2.6** of the Contract because of Force Majeure.

2.5.2. No Breach of Contract

The failure of a Party to fulfill any of its obligations under the Contract shall not be considered to be a breach of or default under, this Contract insofar as such inability arises from an event of Force Majeure, provided that the party affected by such an event;

- a. has taken all reasonable precautions, due care and reasonable alternative measures to carry out the terms and conditions of this Contract, and
- b. has informed the other Party as soon as possible about the occurrence of such an event.

2.5.3. Extension of Time

Any period within which a Party shall, under this Contract, complete any action or task or additional task shall be extended for a period equal to the time during which such Party was unable to perform such activities as a result of Force Majeure or on the advice of Client.

2.6. Termination

2.6.1. **By the Client**

The Client may terminate this Contract, by not less than fourteen (14) days written notice of termination to the Service Provider, to be given after the occurrence of any of the events specified in paragraphs (a) through (g) of this **Clause 2.6.1**:

- a) if the Service Providers do not remedy a failure in the performance of their obligations under the Contract,
- b) if the Service Provider becomes insolvent or bankrupt;
- c) if, as the result of Force Majeure, the Service Provider/s are unable to perform a material portion of the Services for not less than sixty (60) days; or
- d) if the Service Provider/s, in the judgment of the client has engaged in corrupt or fraudulent practices in competing for or in executing the Contract.
- e) If The Service Provider's employees commit a serious crime within the premises which can result in police action under Penal Code of Islamic Republic of Pakistan.
- f) if the Service Provider does not maintain a Performance Guarantee under **Clause 3.12**
- g) if Service Provider materially or consistently breaches the Contract including failure to correct performance deficiencies as mentioned under the **Clause 7.2**.
- h) Client in its sole discretion, may terminate the Contract, in whole or in part, at any time for its convenience. The notice of termination shall specify that termination is for the Client's convenience, the extent to which performance of the Service Provider under the Contract is terminated, and the date upon which such termination becomes effective.

2.6.2. By the Service Provider

The Service Provider may terminate this Contract, by not less than sixty (60) days" written notice to the Client, such to be given, if the Client fails to pay any amount to Service

HOK-M-93 Page **50** of **66**

Provider under this Contract and not subject to dispute pursuant to **Clause 7** within forty-five (45) days after receiving written notice from the Service Provider that such payment is overdue.

2.6.3. Payment upon Termination

Upon termination of this Contract under **Clauses 2.6.1 or 2.6.2,** the Client shall make the following payments to the Service Provider:

- a) Payment of services under **Clause 6** for Services satisfactorily performed by the Service before the effective date of termination;
- b) except in the case of termination under paragraphs (a), (b), (d), (e), (f) of **Clause 2.6.1**, reimbursement of any reasonable cost incident to the prompt and orderly termination of the Contract.
- c) If the total amount already released by client exceeds any payment due to the Service Provider, the difference shall be recovered from the payable amounts and/or the Retention Money/Performance Security.
- d) In case of termination under **Clauses 2.6.1 except under Paragraphs** (c) and (h), performance security shall be forfeited.

3. Obligations of the So	ervice I	Provider
3.1. General		The Service Providers shall perform the Services in accordance with the Description of the Services and the Activity Schedule, and carry out their obligations with all due diligence, efficiency, and economy, in accordance with generally accepted professional techniques and practices, and shall observe sound management practices. The Service Provider shall always act in good faith in respect of any matter relating to this Contract or to the Services, and shall at all times support and safeguard the Client's legitimate interests in any dealings with Sub Service providers or third parties.
	3.1.2.	The Service Provider will ensure continuity of services without interruption as per requirement.
	3.1.3.	In the course of the performance of the services the Service Provider shall comply with all requirements of the Client.
	3.1.4.	The Service Provider shall comply with all applicable laws, rules and regulations, instructions and customary practices of the Client in Pakistan.
	3.1.5.	The Service Provider shall promptly notify the Client of any matter coming to their knowledge that could have a material effect on the business or affairs of the Client.
	3.1.6.	
3.2. Indemnity	3.2.1.	The Service Provider agrees to indemnify the Client and hold it harmless against all liabilities, including jumps of the control of the contr

HOK-M-93 Page **51** of **66**

3. Obligations of the Se	ervice I	Provider
or obligations of the se		and cost of litigation, for anything done or omitted by the
		service provider in the execution of this Contract.
	3.2.2.	Any claims of service provider's current employees or ex-
		employees, or associates, or their heirs whether against the
		Service Provider, other Service Providers working within
		the same premises or any other person, regarding deals
		made at personal level by the staff or personal matters or
		deals carried out in whatsoever form, manner or capacity.
	3.2.3.	Any Government Permits, Licenses, etc. that may be
		required for performing the services contemplated under
		the Contract.
	3.2.4.	Any tax, government duties, insurance contributions and
		other taxes or social security contributions in respect of
		Service Provider's employee(s) or sub-service provider of
		Service Provider together in each case with any interest,
		fines or penalties thereon
	3.2.5.	All claims of compensation by an employee of Service
		Provider, his family or legal heirs or any other agency,
		autonomous body, any NGO or government department,
		arising from injury, disability, ill health or death of any of his
		employees during the currency or expiry of this Contract
		while performing any services under this Contract or any
		claim regarding the medical care or treatment expenses
		submitted by the employee or ex-employee of the Service
3.3. Conflict of	221	Provider or their legal heirs. Service Provider and Service Provider's employee (s)
Interests	3.3.1.	Not to Benefit from Commissions and Discounts.
interests		Payment against the services under Clause 6 shall
		constitute sole payment to the Service Provider. The Service
		Provider shall not accept for their benefit any trade
		commission, discount, or similar payment in connection
		with activities pursuant to this Contract, and in discharge of
		their obligations under this Contract., The Service Provider
		shall ensure that the Service Provider's Employee(s), or
		their affiliates shall not receive any additional payment.
	3.3.2.	<u>Prohibition of Conflicting Activities</u>
		a) Neither the Service Providers nor their affiliates shall
		engage, either directly or indirectly, in any activities
		during the term of this Contract, any business or
		professional activities in the Islamic Republic of
		Pakistan which would conflict with the activities
2.4 Confidentiality	2 / 1	assigned to them under this Contract; Information relating to evaluation of bids and
3.4. Confidentiality	3.4.1.	Information relating to evaluation of bids and recommendations concerning to award of the contract shall
		not be disclosed by the Bank to the Service Provider or to
		any other person who is not officially concerned with the
		process, until the announcement of the result of evaluation.
	3.4.2	The Service Provider shall not disclose or attempt to make
	0.1.2.	public any information relating to the bidding documents,
		bidding process and award of the contract to any person or
		entity without the Bank's prior written consent.
	3.4.3.	In case of any disclosure related to the bidding process and
		contractual obligations at any stage by any Service

For Bank Significant

HOK-M-93 Page **52** of **66**

3. Obligations of the So	ervice Provider
<u> </u>	the Bank may reject its bid and/or terminate the contract
	Service Provider.
3.5. Contractual Liability Insurance	3.5.1. From the Commencement Date until the expiry of the Contract, the risks of personal injury, death, and loss of or damage to property of SBP BSC and third Party due to the negligence of the Service Provider, its employees, associates, sub-Service Provider, assigns etc. (including, without limitation, the tiles, cables, wood works, paint/polish, flower pots, plants, fixtures, metallic items etc.), all such risks are Service Provider's risks. The Service Provider shall have to make good all damages/losses to SBP BSC. In case of failure, SBP BSC reserve all legal rights including but not limited to deduction from any money of the Service Provider with the Bank. 3.5.2. The Service Provider shall indemnify and keep indemnified SBP BSC, at all times against any loss, claim, damage, charge occurred to SBP BSC due to negligence or fraud committed by Service Provider or its employee. The Service Provider may, to protect themselves, obtain "Contractual Liability Insurance" to cover all claims related to Negligence / Fraud/theft if any, committed by the Service Provider or its employees but this is not obligatory. If the Service Provider obtains the above insurance, Service Provider shall be responsible to indemnify SBP BSC regardless of the payment of the insurance amount paid by the insurance company to the Service Provider. Failure of the Service Provider to pay the SBP BSC's claim shall authorize SBP BSC to deduct the claimed amount from the amount payable to
3.6. Service Providers' Actions Requiring Client's Prior Approval 3.7. Independent Service Provider Status	3.6.1. The Service Provider shall obtain the client's prior approval in writing before taking any of the following actions: a) entering into a subcontract for the performance of any part of the Services, b) changing the schedule of activities; c) any other action that may be specified in the SCC. 3.7.1. The parties agree that this contract creates an independent Service Provider relationship, not an employment relationship. The Service Provider acknowledges and agrees that the client will not provide the Service Provider or the Service Provider's employee(s) any fringe benefits or for the reimbursement of any expenses, including without limitation any medical or pension payments, and that income tax/withholding tax is Service Provider's responsibility. 3.7.2. The Service Provider shall be exclusively responsible for paying the salary and other emoluments and providing the benefits to which each of The Service Provider employee (s) is entitled under his/her contract with The Service Provider. All claims made by the Service Provider's employee (s) shall be dealt with exclusively by the Service Provider. 3.7.3. None of the Service Provider's employee (s) shall be entitled to seek employment with the client merely on the ground that he/she had been posted by the Service Provider at any of the premises of SBP BSC for performance of this

For Ban PARIMEN

HOK-M-93 Page **53** of **66**

3. Obligations of the S	ervice Provider		
3.8. Compliance	3.8.1.The Service Provider shall be responsible to comply with all		
with all the	applicable laws of the land to fulfill the regulatory payments		
Regulatory	under Labor Laws which includes but not limited to:		
Requirement	f. Payment of at-least minimum		
Requirement	wages/salaries/remuneration as notified by the		
	respective Government.		
	g. Ensure EOBI/Social Security registration of its		
	resources and regular payment of contributions.		
	h. Group Life and Medical Insurance.		
	i. Casual, medical and maternity or any other leaves as		
	per applicable laws.		
	j. Any other requirement as applicable under the		
	relevant law.		
	3.8.2. The Service Provider will ensure that the terms and		
	conditions of employment/ service of its employees are		
	compliant and in accordance with the applicable labor laws		
	existing in Pakistan and any of the Provinces in Pakistan.		
	3.8.3. The Service Provider shall take all practicable steps to ensure		
	that all of its resources comply with the Applicable Law.		
3.9. Reporting	3.9.1. The Service Provider shall submit to the client the reports		
Obligations	and documents specified in the Bidding document or		
a sangarasa	otherwise, as and when required by the client.		
3.10. Documents	3.10.1.All, reports, and other documents and software submitted (if		
Prepared by the	any) by the Service Provider under Clause 3.9 shall become		
Service	and remain the property of the client, and the Service		
Providers to Be	Provider shall during the execution of Contract and in any		
the Property of	case not later than upon termination or expiration of this		
the Client	Contract, deliver all such documents and software to the		
	client, together with a detailed inventory thereof. The Service		
	Provider may retain a copy of such documents and software.		
	Future use of these documents by the Service Provider shall		
	be subject to approval of Client.		
3.11. Penalties /	3.11.1.For each deficiency and poor service, SBP BSC will impose a		
Liquidated	penalty amounting up to 1.5 times of its daily respective		
Damages	services fee (i.e. monthly fee of respective services for		
	ongoing year/30) per event without prejudice to any other		
	remedy or relief available to SBP BSC under the Contract and		
	/ or applicable law. The deduction of the penalty does not		
	relieve the Service Provider to provide services as mentioned		
	in the Agreement.		
	3.11.2.In addition to the above penalty, the SBP BSC would be		
	entitled to deduct actual cost of repairing or replacement		
	thereof, if damage occurs to any property of SBP BSC and / or		
	third party due to any fault on the part of the Service		
	Provider.		
	3.11.3. Without prejudice to above, the Service Provider shall have		
	to deploy extra resources, to meet the service quality		
	standards at no extra cost to SBP BSC as and when required.		
	3.11.4. Client may impose penalty equal to 1/30 of the respective		
	monthly invoice in case of non-disbursement of		



HOK-M-93 Page **54** of **66**

3. Obligations of the So	ervice Provider
- U	salaries/wages/remuneration within the date specified in
	the Contract.
3.12. Performance	3.12.1. The Service Provider shall furnish a Performance Guarantee
Guarantee	equal to 5% of the Contract Price stated in Letter of Award /
	Acceptance in the shape of Bank Guarantee/Bank draft issued
	from schedule bank in Pakistan, which will be valid 28 days beyond the Contract Period. Notwithstanding anything
	contained in the Contract and / or applicable law the
	Performance Guarantee shall be forfeited if the Services
	Provider fails to perform its obligations under the Contract.
3.13. Early	3.13.1.The Service Provider shall warn SBP BSC in writing at the
Warning by the	earliest opportunity of specific likely future events,
Service Provider	problems or circumstances whether on Service Provider's
	part or on SBP BSC's part, that may adversely affect the quality of Services. The Service Provider should also
	provide the details of likely corrective measures required.
	3.13.2. SBP BSC shall evaluate and decide the corrective measure to
	be adopted as soon as reasonably possible.
	3.13.3.If the Service Provider fails to give an early warning without
	any justified reason he shall be held responsible for all the
3.14. Declaration	consequences thereof.
3.14. Deciaration	3.14.1. The Service Provider hereby declares that it has not obtained
	or induced the procurement of any contract, right, interest, privilege or other obligation or benefit from SBP BSC through
	any corrupt business practice.
	3.14.2. The terms and conditions and the Schedules thereto
	represent the entire Contract and understanding between
	SBP BSC and the Service Provider, in relation to the subject
	matter hereof and supersede all previous agreements
	and/or understandings between the parties in relation
	thereto.
	3.14.3. If any provision of the Contract is found by any court or
	competent authority to be invalid, unlawful or
	unenforceable, that provision shall be deemed not to be a
	part of the Contract and it shall not affect the enforceability
	of the rest of the Contract.
	3.14.4. Unless expressly provided, no term of this Contract is
	enforceable by any third party.
	3.14.5. This Contract is personal to Service Provider and Service
	Provider shall not assign or subcontract any of its rights or
	obligations under it without SBP BSC's prior written consent.
	Any subcontracting shall be on terms consistent with these
	Conditions.
	3.14.6. The Contract shall be governed by the laws of Pakistan and
	Service Provider and SBP BSC agree to submit to the
	exclusive jurisdiction of the courts in Pakistan.



HOK-M-93 Page **55** of **66**

4. Scope of services		
4.1. Description of Services	4.1.1. The scope of services to be performed by the Service	
to be performed by the	Provider are described at Section VI-Part-1.	
Service Provider		

	5. Obligations of the Client			
5.1. Provide information about the code of conduct	5.1.1. The Client shall at the request of Service Provider, provide the information on the code of conduct and security procedures. The Client shall immediately notify the Service Provider of any changes to the same during the continuance of this Contract.			
5.2. Change in the Applicable Law	 5.2.1.If, after the date 7 days prior, to the latest date for submission of tenders for the Contract there occur changes to any Federal and/or Provincial Law or any regulation or bye-law, notification of any local or other duly constituted authority, or the introduction/revision of any such Federal and/or Provincial Law, regulation or bye-law especially labor laws regarding revision in minimum wage or any other statuary benefits for the labor force, notification which causes addition or reduction in the cost of Service such additional or reduced cost shall be added to or deducted from the Contract Price. 5.2.2.The Service Provider shall substantiate price adjustment with supporting relevant documents including government notifications etc. in evidence. 			
5.3. Services and	5.3.1. The Client shall make available to the Service Provider the			
Facilities 5.4. Assistance and Exemptions	Services and Facilities, if any provided in the Contract. 5.4.1. No assistance regarding exemption will be provided by the Client.			
5.5. Access To The Buildings/ Premises And Stores	 5.5.1. Before the commencement of the Contract, SBP BSC will provide access of Service Provider and Service Provider's employee(s) (after verification and clearance by the police or other investigation agency as per SBP BSC Security Protocol), to all concerned parts of the buildings/ Premises where Services are to be provided under the Contract. 5.5.2. The Service Provider shall allow and ensure easy access of authorized person(s) of SBP BSC to his office, store or other areas under his control while providing the Services under the Contract. 			
5.6. Performance / Completion Certificate	5.6.1. SBP BSC will provide a Performance certificate during pendency of Contract and completion Certificate after completion of Contract to the Service Provider on his written request.			

6. Payments to the Service Provider				
6.1. Payments	6.1.1. The Service Provider's payment shall not exceed the Contract Price/rates and shall be a fixed lump-sum including all other costs incurred by the Service Providers in carrying out the Services. Except as provided in Clause 5.2 , the Contract Price may only be increased above the amounts stated in Clause 6.2 if the Parties have agreed to additional payments under Clauses 2.4 and 6.3 .			
6.2. Contract Price	6.2.1. The Contract Price means sums stated in Notification of Award as payable to Service Provider for execution of Services			

For Bank Signwision

HOK-M-93 Page **56** of **66**

6. Payments to t	he Serv	ice Provider	
o. Tayments to t		remedying defects therein as well as additional services and	
		extensions.	
		Prices payable to the Service provider as stated in the Contract are	
		not subject to any adjustment during the performance of the	
		contract except as otherwise specified in the Contract.	
6.3. Payment for	6.3.1.	In case of additional services beyond daily service duration are	
Additional Services		required, the Service Provider shall have to arrange and provide the	
Sel vices		additional services on written or verbal request of SBP BSC at any	
		time. SBP BSC shall make an additional payment to the Service	
		Provider on pro-rata basis of the relevant BOQ item/Price Schedule	
		as following equation:	
	Man	thly sharges as Description of normal and	
		thly charges as / Resources as per proposed he Price Schedule / management plan / (0 km see)	
	per t	/ (9 hours)	
		30	
6.4. Terms	6 <u>4</u> 1 Th	ne payments shall be made to the Service Provider on monthly basis	
and		ter adjustment of any claims/ deduction against the Service	
Conditions of		ovider.	
Payment		case of unavailability of services, SBP BSC will make deductions	
	accordingly. However, deduction mechanism will be based on formula		
	us	ed for pro-rata calculation as mentioned below:	
	Monthly charges Resources as per		
	as per the Price / proposed		
	Schedule management plan * which services		
	30 remained unperformed		
	Temanica unperformed		
	6.4.3.Payments will be made upon submission of invoice/s, after		
	confirmation of satisfactory services by authorized officer of SBP BSC		
	on a monthly basis. Furthermore, payments will be made to the service provider as per actual services rendered against the services after		
	•	justing the additional/ unperformed services or reduction of	
		rvice, as mentioned in the Contract or subsequently conveyed by the	
		ient.	
		ith every monthly invoice for release of payment, the Service	
		ovider shall attach evidence of timely disbursement of	
		ages/salaries/remuneration and other regulatory payments to its	
		sources used under this contract for the preceding month.	
	1 6	sources used under this contract for the preceding month.	
6.5. Currency of	6.5.1.	All Payments shall be made in Pak. Rupees.	
Payment			
6.6. Taxes and	6.6.1	All applicable taxes shall be deducted by SBP BSC at source unless	
Duties		a valid tax/ duty exemption certificate is submitted by the Service	
		Provider.	
	6.6.2	The Service Provider is bound to pay provincial and other taxes,	
	0.0.2	duties, liabilities, license fees etc. due to concerned department	
		directly, and is bound to discharge all duties and liabilities	
		uncerry, and is bound to discharge an duties and habitudes affective	

Page **57** of **66** HOK-M-93

6. Payments to the Service Provider								
		regard. Any concealing facts in this regard would lead to						
		termination of Contract and blacklisting etc.						

7. Quality Control		
7.1. Performance	7.1.1.	The Service Provider will maintain the highest level of service
Standards		standards as per best industry practice or as specified in this
		contract.
7.2. Correction of	7.2.1.	SBP BSC shall check the Service Provider's work and bring to
Defects, and		the knowledge of the Service Provider of any defects that are
Penalty for		found. Such checking shall not affect the Service Provider's
Lack of		responsibilities.
Performance	7.2.2.	The SBP BSC's authorized Officer shall serve a written warning to the Service Provider to improve the quality of Services and remove the deficiencies. For each deficiency and poor service, SBP BSC will impose a penalty as per Clause 3.11.
	7.2.3.	The Service Provider shall adhere to service standards accordingly and cover the performance gaps. Failing which, SBP BSC may issue notice to the Service Provider.
	7.2.4.	If the Service Provider fails to deliver the Services as per Contract, despite previous warnings in writing persistently or flagrantly neglecting to comply with any of his obligations under the Contract, SBP BSC may after giving the 14 days' notice to Service Provider terminate the Contract. Notwithstanding anything in contained in the Contract and / or applicable law, the Performance Guarantee shall be forfeited and SBP BSC shall also debar the Service Provider from participation in future Contracts.

	8. Resolution of Disputes
8.1. Disputes Resolution Procedure	 8.1.1. If any dispute arises between the parties (Service Provider and SBP BSC), regarding the performance of the Services or anything contained in the Contract, the matter shall be referred to the Director Engineering or any other officer authorized by the competent authority at SBP BSC who will examine the matter in detail and give a decision. 8.1.2. In case any party is not satisfied with the decision, the matter shall be referred to arbitration in accordance with the Arbitration Act, 1940.

9. Health, Safety, Utilities, First Aid Facilities			
9.1. Health, Safe	e ty, 9.1.1.	The Service Provider shall comply with all statutory and	
Environment a	ınd	regulatory requirements related to Health, Safety,	
Security (HSE&	S)	Environment and Security (HSE&S) as well as SBP BSC's	
		instructions, procedures or policies related thereto, at no	
		additional cost to SBP BSC. The costs of supplying and/or	
		doing all such things required for the purpose as per	
		industry practice shall be deemed to be included in the	
		amounts payable under this Agreement to the Service	
		Provider.	
	9.1.2.	SBP BSC may periodically check the Service	
		compliance with standard HSE&S practices and conduct.	
		CIVIL	
For Bidder (Sign and Stamp)	For Bidder (Sign and Stamp) For Bank (Signwood Stand)		
		OF PARIMENT	

HOK-M-93 Page **58** of **66**

9.2. Electric Power Supply, Water Supply, Telephone etc.	safety inspections as and when it deems fit. The Service Provider shall ensure that SBP BSC's recommendations and industry standards in this regard are implemented without any delay. 9.1.3. The Service Provider shall provide SBP BSC information about its working practices, materials and equipment and shall operate in a manner which does not compromise SBP BSC's security or environment standards and the safety and health of its employees and other people. The Service Provider shall also provide SBP BSC with any information which it may have related to a potential or actual security threat to SBP BSC. 9.1.4. The Service Provider shall certify in writing that its personnel are fully trained to execute the Services safely and shall ensure that they understand all risks and hazards associated with the Services. 9.1.5. The Service Provider shall pay special attention to the following environmental protection measures: a) Use of clean fuels to minimize air polluting emissions. b) Control of other air pollutants. c) Recovery and recycling of usable materials. d) Control of vehicle noise. e) Control of vehicle noise. e) Control of robise from power facilities. f) Limitation of Vibrations. g) Preservation of natural land to the extent possible. h) Preservation of archaeological Sites. i) Careful handling, storage and utilization of hazardous radioactive materials, toxic chemicals etc. 9.1.6. SBP BSC reserves the right to terminate this Contract without notice to the Service Provider in the event of violation of any of the above instructions by the Service Provider and related HSE&S requirements of SBP BSC communicated to the Service Provider from time to time. 9.2.1. Water and electric power for rendering the services under the Contract will be provided by SBP BSC. Expense regarding the required cables/wires, switches etc. for Service Provider's tools/ equipment shall have to be borne by the Service Provider. The Service Provider shall make his own arrangement at his own expenses for the telephone, compute
	Service Provider's tools/ equipment etc. shall be arranged by the Service Provider and placed at location allocated by
9.3. First aid Facilities	SBP BSC. 9.3.1. The Service Provider shall provide its resources with free
7.5. First aiu ratinues	first-aid facilities and treatment at the premises and shall, for this purpose, keep a properly equipped first aid kit at the premises.

10. Corrupt and Fraudulent Practices		
10.1. Corrupt &	10.1.1.The Client requires compliance with its policy regarding	
Fraudulent	corrupt and fraudulent practices. In pursuit of this policy,	
Practices	the Client follows, inter alia, the instructions contained in	
	Rule 2(1)(f) of PPR 2004 which defines:	

HOK-M-93 Page **59** of **66**

"corrupt and fraudulent practices" in respect of procurement process, shall be either one or any combination of the practices including,ii. "coercive practices" which means any impairing or harming or threatening to impair or harm, directly or indirectly, any party or the property of the party to influence the actions of a party to achieve a wrongful gain or to cause a wrongful loss to another party; "collusive practices" which means any arrangement iii. between two or more parties to the procurement process designed to stifle open competition for any wrongful gain, and to establish prices at artificial, non-competitive levels: "corrupt practices" which means the offering, giving, iv. receiving or soliciting, directly or indirectly, of anything of value to influence the acts of another party for wrongful gain; "fraudulent practices" which means any act or ν. omission, including a misrepresentation, that knowingly or recklessly misleads, or attempts to mislead, a party to obtain a financial or other benefit or to avoid an obligation; and "obstructive practices" which means harming or νi. threatening to harm, directly or indirectly, persons to influence their participation in a procurement process, or affect the execution of a contract;" 10.2. Mechanism 10.2.1. The client will terminate the contract if it determines that the Service Provider recommended for award has, directly Blacklisting and cross-debarring or through an agent, engaged in corrupt, fraudulent, collusive or coercive and obstructive practices in competing for the contract in question; 10.2.2. The client will sanction a Service Provider, including declaring the Service Provider ineligible, either indefinitely or for a stated period, to be awarded a client's contract if at any time it determines that the service provider has, directly or through an agent, engaged in corrupt, fraudulent, collusive or coercive and obstructive practices in competing for, or in executing Client's contract: and 10.2.3. Under Rule 19 of PPR-2004, "The Client can inter alia blacklist Service Provider found to be indulging in corrupt or fraudulent practices. Such barring action shall be duly publicized and communicated to the PPRA. **NATURE OF** OFFENSE / MEANS OF VERIFICATION **FAULT** Corruption Actual instance verifiable as per law of land and applicable rules and regulations of SBP **Deviation** If the bidder deviates from its prior

from

commitment

commitment

by the bidder.

or

regarding the bid or proposal submitted

declaration

HOK-M-93 Page **60** of **66**

The state of the s		T 1		
	Fraud	Cross verification of documentary		
	undertakings submitted by Contractor/			
	Bidder/Consultant/Supplier Collusion Results of Bid/Proposal analysis			
		resulting in substantive evidence of		
		collusion		
	Performance	Documented evidence in form of		
	Deficiencies	performance deficiencies not suitably		
		responded or defended by Contractor/		
	Bidder/ Supplier/ Consultant			
	However such barring action shall be undertaken only after			
	Service Provider who is to be barred and blacklisted shall be			
	accorded adequate opportunity of being heard. Decision of the			
	Blacklisting Committee of SBP BSC will be final and conclusive.			
10.3. Beneficial	10.3.1.Beneficial Ownership information			
Ownership	For Services/works worth Rs.50M or above, the bidder			
information	shall provide Beneficial Ownership information on the			
	prescribed Form. Failure to provide the required			
	information of the beneficial ownership by the company or			
	submission of false or partial information, the procuring			
	agency shall:			
	~ .	o ,		
		rule 19(1)(a) of Public Procurement Rules, 2004,		
		ct the bid of the said company.		
	ii. Reject the blu of the salu company.			

HOK-M-93 Page **61** of **66**

SPECIAL CONDITIONS OF CONTRACT (SCC)

The following Special Conditions of Contract shall supplement the General Conditions of Contract. Whenever there is a conflict, the provisions herein shall prevail over those in the General Conditions of Contract.

Number of GCC Clause	Amendments of, and Supplements to, Clauses in the General Conditions of Contract		
1.1.1(b)	The Client is SBP BSC HEAD OFFICE, KARACHI		
1.1.1(c)	The Service Provider is [insert name]		
1.1.1(d)	The Title & Reference of the procurement is;		
	Continuous and Un-Interrupted Management Services of Screw Type Chillers installed at BSC House Plant and 3rd Floor, Main Bank Building, State Bank of Pakistan, Karachi		
	Reference No: HOK-M-93		
1.5	The addresses are:		
	Client: SBP Banking Services Corporation (BSC) Head Office Karachi		
1.6	The Authorized Representatives will be nominated in the Work order.		
3.12	5% of the Contract Price stated in Letter of Acceptance / Award in the form of Pay Order/Demand Draft/Deposit at Call/Bank Guarantee from any Scheduled Bank registered in Pakistan.		
	The Performance Security would remain valid 28 days beyond the contract		
	expiry date.		
6.5	Payment shall be made in Pak Rupees.		
8.1.2	Place of arbitration would be Karachi.		



HOK-M-93 Page **62** of **66**

STANDARD FORMS

(Note: Standard Forms provided in this document for securities are to be issued by SBP BSC. In case the bidder chooses to issue a bond for accompanying his bid or performance of contract or receipt of advance, the relevant format shall be tailored accordingly without changing the spirit of the Forms of securities.)



HOK-M-93 Page **63** of **66**

SECTION VIII- Contract for Continuous and Un-Interrupted Management Services of Screw Type Chillers installed at BSC House Plant and 3rd Floor, Main Bank Building, State Bank of Pakistan, Karachi

This Contractat SBP Banking Services Corporation Head office is made
at Karachi the day of the month of 202
<u>BETWEEN</u>
SBP Banking Services Corporation established under SBP Banking Service Corporation
Ordinance 2001, having its office located atrepresented
by the (hereinafter referred as "SBP BSC") (which expression,
wherever the context so required, shall include its heirs, executers, assigns, and administrators
as the case may be). of the First Part. AND
M/a
M/s a partnership, firm, company having its office located
at, an adult, resident of
(hereinafter referred as "Service Provider") (which expression, wherever the
context so required, shall include its heirs, executers, assigns, and administrators as the case may
be) of The Second Part.
WHEREAS SBP BSC is desirous of from an
independent Service Provider for which purpose SBP BSC issued an Invitation to Bid (ITB) No.
$ED/_{-}/_{-}$ calling for bids in the manner as provided for in the Public Procurement Rules, 2004
(PPR-2004).
(11 K-2004).
AND WHEREAS the Service Provider submitted its bid in response to the SBP BSC's ITB and the
bid of the Service Provider has been accepted by SBP BSC, where after, SBP BSC has offered to the
Service Provider to perform the services as per this contract.
AND WHEREAS the Service Provider having represented to SRP RSC that they have the required

AND WHEREAS the Service Provider having represented to SBP BSC that they have the required professional skills, and personnel and technical resources, have agreed to provide the Services on the terms and conditions set forth in this contract at an agreed contract price.

NOW THEREFORE the parties hereto agree as follows:

The following documents attached hereto shall be deemed to form an integral part of this contract:

- General Conditions of Contract;
- Special Conditions of Contract;
- Instructions to bidders and bid data sheet
- Bidding Documents-Section V
- Bidding Documents-Section VI
- Beneficial Ownership (if applicable)
- Letter of Acceptance
- Performance Guarantee
- Addendum / corrigendum (If any)
- Integrity Pact (If applicable)
- Non-Disclosure Agreement (If applicable)



HOK-M-93 Page **64** of **66**

The mutual rights and obligations of SBP BSC and the Service Provider shall be as set forth in the Conditions of Contract and Invitation to Bid (ITB), in particular:

- a) The Service Provider shall carry out the Services only through its regular / contracted employees, 'in accordance with the provisions of the Conditions of Contract and ITB; and
- b) SBP BSC shall make payments to the Service Provider in accordance with the provisions of the same after deduction of all the applicable taxes required under the existing laws at the time of payment and recover damages, if any, during provision of the services.

IN WITNESS WHEREOF, the Parties hereto have caused this contract to be signed in their respective names as of the day and year first above written.

or and on benaif of SBP Banking Services Corporation
Authorized Representative] (Name, Designation and signature) Vitness-1:
igned by:
NIC #:
Vitness-2:
igned by:
NIC #:
or and on behalf of
Authorized Representative] (Name, Designation, Signature, CNIC Number
Vitnesses-1:
igned by:
NIC # :
Vitness-2:
igned by:
NIC #:



HOK-M-93 Page **65** of **66**

(INTEGRITY PACT)

DECLARATION OF FEES, COMMISSION AND BROKERAGE ETC. PAYABLE BY THE SUPPLIERS OF GOODS, SERVICES & WORKS IN CONTRACTS WORTH RS. 10.00 MILLION OR MORE

	Contract No Dated Contract Value:	
	Contract Title:	
	[name of Supplier] h the procurement of any contract, right, inte	ereby declares that it has not obtained or induced erest, privilege or other obligation or benefit from istrative subdivision or agency thereof or any other any corrupt business practice.
Without limiting the generality of the foregoing, [name of Supplier] represents and was that it has fully declared the brokerage, commission, fees etc. paid or payable to anyone a given or agreed to give and shall not give or agree to give to anyone within or outside Pareither directly or indirectly through any natural or juridical person, including its affiliate, associate, broker, consultant, director, promoter, shareholder, sponsor or subsidiar commission, gratification, bribe, finder's fee or kickback, whether described as consultated or otherwise, with the object of obtaining or inducing the procurement of a contract interest, privilege or other obligation or benefit in whatsoever form from GOP, excession which has been expressly declared pursuant hereto.		mission, fees etc. paid or payable to anyone and not agree to give to anyone within or outside Pakistan aral or juridical person, including its affiliate, agent, omoter, shareholder, sponsor or subsidiary, any or kickback, whether described as consultation fee or inducing the procurement of a contract, right, enefit in whatsoever form from GOP, except that
	arrangements with all persons in respect of	and will make full disclosure of all agreements and or related to the transaction with GOP and has not o circumvent the above declaration, representation
	not making full disclosure, misrepresenting purpose of this declaration, representation interest, privilege or other obligation or benefits.	and strict liability for making any false declaration, g facts or taking any action likely to defeat the and warranty. It agrees that any contract, right, efit obtained or procured as aforesaid shall, without available to GOP under any law, contract or other.
	agrees to indemnify GOP for any loss or dama practices and further pay compensation to G any commission, gratification, bribe, finder	xercised by GOP in this regard, [name of Supplier] age incurred by it on account of its corrupt business GOP in an amount equivalent to ten time the sum of 's fee or kickback given by [name of Supplier] as inducing the procurement of any contract, right, efit in whatsoever form from GOP.
ľ	Name of Buyer:	Name of Seller/Supplier:
5	Signature:	Signature:
[Seal]	[Seal]



HOK-M-93 Page **66** of **66**

FORM OF PERFORMANCE GUARANTEE

(Bank Guarantee)

	Guarantee No
	Executed on
•	SBP Banking Services Corporation)
Name of Guarantor (Scheduled Bank in Pakist	tan) with
address:	
Name of Principal (Service Provider) with	
address:	
Penal Sum of Guarantee (express in words an	.d
figures) Letter of Acceptance No	 Dated
and above said Letter of Acceptance (hereinal said Service Provider we, the Guarantor above Banking Services Corporation (hereinafter ref stated above, for the payment of which sun ourselves, our heirs, executors, administrator these presents.	n pursuance of the terms of the Bidding documents fter called the Documents) and at the request of the ve named, are held and firmly bound unto the SBP ferred as "SBP BSC") in the penal sum of the amount n well and truly to be made to SBP BSC, we bind ors and successors, jointly and severally, firmly by CH, that whereas the Service Provider has accepted
SBP BSC's above said Letter of Acceptance fo	r (Name of Contract)
for the(N	lame of Project).
undertakings, covenants, terms and condition of the said Documents and any extensions to without notice to the Guarantor, which notice perform and fulfill all the undertakings, coverany and all modifications of the said Docum modifications to the Guarantor being hereby to remain in full force and virtue till all requires	shall well and truly perform and fulfill all the ns of the said Documents during the original terms thereof that may be granted by SBP BSC, with or ce is, hereby, waived and shall also well and truly enants terms and conditions of the Contract and of tents that may hereafter be made, notice of which waived, then, this obligation to be void; otherwise rements of Conditions of Contract are fulfilled.
any liability attaching to us under this Guara	ited to the sum stated above and it is a condition of ntee that the claim for payment in writing shall be his Guarantee, failing which we shall be discharged
the Contract, do hereby irrevocably and indep upon the SBP BSC's first written demand with BSC to prove or to show grounds or reasons f stated above, against the SBP BSC's written do	rantor), waiving all objections and defenses under tendently guarantee to pay to SBP BSC without delay hout cavil or arguments and without requiring SBP for such demand any sum or sums up to the amount eclaration that the Principal has refused or failed to or which payment will be effected by the Guarantor t Number.
Provider has duly performed his obligations u obligations and the Guarantor shall pay with	cole and final judge for deciding whether the Service under the Contract or has defaulted in fulfilling said nout objection any sum or sums up to the amount SBP BSC forthwith and without any reference to the

IN WITNESS WHEREOF, the above bounded Guarantor has executed this Instrument under its seal on the date indicated above, the name and corporate seal of the Guarantor being hereto affixed and these presents duly signed by its undersigned representative, pursuant to give of its governing body.

Principal or any other person.

HOK-M-93 Page **1** of **4**



SBP BANKING SERVICES CORPORATION (BSC) ENGINEERING DEPARTMENT HEAD OFFICE KARACHI

CONTINUOUS AND UN-INTERRUPTED MANAGEMENT SERVICES OF SCREW TYPE CHILLERS INSTALLED

AT

BSC HOUSE PLANT AND 3RD FLOOR, MAIN BANK BUILDING, STATE BANK OF PAKISTAN, KARACHI

BIDDING AND CONTRACT DOCUMENTS

VOLUME-II

FINANCIAL BID

JANUARY 2023



HOK-M-93 Page **2** of **4**

Section V- Form for Financial Bid

Form-I Financial Bid Submission Form (Financial Bid Submission Form)

(ON SERVICE PROVIDER'S LETTERHEAD)

Da	te:
То:	
SBP Banking Services Corporation, Head Office	
Dear Sir:	
Having examined the bidding documents, the receipt of which is acknowledged, we, the undersigned, offer requisite services in conformity with the documents as may be ascertained in accordance with the Technical Bid and Schedattached herewith and made part of this Bid.	said bidding
We undertake, in case our Bid is accepted, to deliver the services in accordate Tender Documents and other terms and conditions of the contract.	ance with the
If our Bid is accepted, we will obtain the guarantee of a bank in a sum equitof the contract amount for the due performance of the Contract, in the form presonants.	
We agree to abide by this Bid for a period of 180 (One Hundred Eighty Da date fixed for Bid opening under IB.20 of the Instructions to Bidders, and it shall resupon us and maybe accepted at any time before the expiration of that period.	• •
If our Bid is accepted then until a formal contract is prepared and execu together with your written acceptance thereof and your notification of award, shal binding contract between us.	
We understand that you are not bound to accept the Most Advantageous or any receive.	bid you may
Dated this day of 202	
[Seal & signature] [in the capacity of]	
Duly authorized to sign Bid for and on behalf of	



HOK-M-93 Page **3** of **4**

Form II - Price Schedule The Financial Bid

Name of Bidder
Reference Number:

The bidders must quote the rates for various services mentioned in tender documents, nature of services/service execution area, scope of services and other requirement mentioned in the tender documents Vol-I;

Sr. No.	Description	Fee per Month inclusive of all applicable taxes etc. (Rs.)	Annual Amount (Rs.)
1	(Supervisory Services) Fee		
2	(Technical Operation services) Fee		
3	(Technical Assistance services) Fee		
4	(Technical support services) Fee		
	Т		

Rupees (in	
words):	only

Note:

1. All duties, taxes, liabilities including overheads, transportation charges etc. and other levies payable by the Bidder under the Contract, or for any other cause shall be included in the total Bid price submitted by the Bidder. Prevailing Withholding tax rates (ATL) are as below:

S. No.	Service Category	Rate of Withholding Tax %		
		Company	Other than Company	Registered with PEC
1	Janitorial & Gardening Services	8	10	N.A.
2	Building Maintenance Services , Services for Lifts, Escalators, Generators, HVAC , Split AC	8	10	3
3	PABX Maintenance Services	8	10	N.A.
4	PA Maintenance Services	8	10	N.A.



HOK-M-93 Page **4** of **4**

2. Bid shall be compliant with all the prevailing & applicable laws of Pakistan and any of the Provinces of Pakistan necessary for execution of these services.

- 3. Since participating bidders are required to ensure compliance with relevant laws, therefore, SBP BSC may ask any or all of the bidders whose financial bid will be opened for detailed breakup of financial bid in order to ascertain the economic viability.
- 4. While assessing the economic viability, if SBP BSC found that cost quoted by the any technically qualified bidder is not workable to comply the provisions of contract, SBP BSC reserves the right to reject such bid/s.

Authorized Signature:	
Name and Title of Signatory:	
Name of Bidder:	
Address:	