



**SBP Banking Services Corporation (Bank)
North Nazimabad, Karachi**

C O R R I G E N D U M

**SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF DIFFERENT RATING SPLIT
AIR CONDITIONERS AT SBP BSC (BANK) NORTH NAZIMABAD, KARACHI**

This is with reference to the cited tender which was published on websites of State Bank Pakistan (www.sbp.org.pk) and Public Procurement Regulatory Authority (www.ppra.org.pk) on October 05, 2020.

1. In this regard, the text "***1 TR Wall Mounted Inverter type AC with net cooling capacity of minimum 24,000 BTU/h and EER not less than 3.5 –cool type only***" as mentioned in the BOQ item No. 01(C)(Vol-II) may please be read as "***1 TR Wall Mounted Inverter type AC with net cooling capacity of minimum 12,000 BTU/h and EER not less than 3.2 –cool type only.***"
2. The minimum required EER in Technical Compliance Standards and BOQ item no. 01(a) and item 01(b) is **3.2** and **2.7** instead of **3.5** & **2.9**.
3. The bidder shall submit original brochures of companies as required in Sr.no. 10 of *Technical Bid Evaluation Criteria*. Failing which, the bidder will be disqualified from the bidding.

All other details shall remain unchanged.

- Sd/-

Chief Manager
State Bank of Pakistan
SBP BSC (Bank) North Nazimabad, Karachi
Phone: 021- 99260705-8, Ext: 219