

ADDENDUM / CORRIGENDUM NO. 02**SUPPLY, INSTALLATION & MAINTENANCE OF STRONG ROOM DOORS AT VARIOUS OFFICES OF SBP BSC**

In order to provide necessary clarification to facilitate the prospective bidders, this Addendum No.2 is issued, which shall be included in the Bidding Documents. The Bidder shall note & take into consideration the following additions / corrections in the Bidding Documents for the subject work issued to them:

These addition/ deletion/ amendments will form an integral part of the Bidding Documents. The Bidder shall acknowledge the receipt of this addendum to the Employer. The addendum, duly signed and stamped, shall be attached with the Volume – I of the Bidding Documents and submitted along with the Bid on or before the due date of submission.

Sr #	Description / Reference / Clarifications Sought by Bidders / Corrections	<u>Addendum / Corrigendum</u>
1.	VOLUME – I SECTION V : SCHEDULE OF REQUIREMENTS & TECHNICAL SPECIFICATIONS	
	<p><u>Existing sub-provision</u></p> <p><u>High Security Locks (HSL):</u></p> <p>1. Minimum requirement of High Security locks should conform to class D (EN 1300 or its approved equivalent) subject to compliance with Purchaser's requirements and approval.</p> <p><u>Clarification No.9 dated: October 7th, 2024</u></p> <p>Electronic and mechanical locks are required to comply EN-1300 Class D specifications. However, features such as holiday time lock, remote management and audit are required for electronic locks.</p>	<p>Specifications of Electronic and Mechanical Key locks wherever appearing in the tender documents are replaced as under:</p> <p>“Total number of locks in a door shall conform to the requirements of Table-3 of EN 1143-1. Electronic Locks for Grade-XIII Doors shall conform to EN 1300 Class D. No Mechanical Key Lock shall be provided in Grade-XIII Doors. For Grade-XI Doors, Electronic and Mechanical Key Locks (in 1:2 combination) shall conform to EN 1300 Class C. For Security Window, only Mechanical Key Locks shall be provided conforming to EN 1143-1. Features such as holiday time lock, remote management and audit are required for Electronic locks.”</p>

