


**SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF 3 NOS. 4TR CONVENTIONAL FLOOR STANDING TYPE SPLIT AC UNITS AT SBP BSC
LAHORE**

TECHNICAL BID EVALUATION REPORT


Name of Procuring Agency	State Bank of Pakistan Banking Services Corporation (Bank) Lahore.
Method of Procurement	PPRA Rule 36-b i.e Single stage - two envelope procedure.
Title of Procurement	SUPPLY, INSTALLATION, TESTING & COMMISSIONING OF 3 NOS. 4TR CONVENTIONAL FLOOR STANDING TYPE SPLIT AC UNITS AT SBP BSC LAHORE.
PPRA Ref. No. (TSE)	TS488192E
Date & Time of Bid Closing	07-09-2022 till 03:00 PM
Date & Time of Bid Opening	07-09-2022 @ 04:00 PM
No. of Tenders obtained by firms	Bidding Documents electronically available on website


Sr. No	Category	Criteria	Minimum Acceptable	Document/ Evidence Required	Submissions/ Compliance by the Bidders	
					M/s. Climate Control	Remarks
1		Bid is unconditional			-	OK
2		Duly filled and signed Form of Bid.			-	OK
3		Bid Security is required as per clause IB-13.1. Bid Security in Original is to be attached with Technical Proposal.			-	OK
4	i	Name of Company			M/s. Climate Control	
	ii	Company Legal Status			Individual / Sole Proprietor	
	A.	i-Copy of CNIC				OK
		ii-Affidavit that firm is individual / Sole proprietor				OK
	B.	i-Partnership Deed			N/A	



Evaluation Criteria				Submissions/ Compliance by the Bidders		
				M/s. Climate Control		
Sr. No	Category	Criteria	Minimum Acceptable	Document/ Evidence Required	Submittal	Remarks
	In case of Associated of Persons (AOP)		ii-Any other relevant Document			
			iii-No. of Partners			
			iv-Nos. of partners along with CNIC			
			i-Copy of Article of Association / Memorandum			
	C. In case of (Pvt.) limited		ii-Form 29		N/A	
			iii-Form A			
			iv-Nos. of Directors along with copy of CNIC			
			a) Telephone b) Mobile No. c) fax numbers (if any) d) email address (if any) e) Postal Address			
iii. Contact details						
5		Affidavit on non-judicial stamp paper of not being blacklisted , declared in-eligible or debarred by any organization / department for corrupt or fraudulent practices.			Submitted	OK
6		Bidder must be registered with FBR in Income Tax and must active taxpayer as per Federal Board of Revenue (FBR's) revenue Data base i-e Active Tax Payer List (NTN).			Submitted	OK
7		Bidder must be registered with FBR in General Sales Tax and must active tax payer as per Federal Board of Revenue (FBR's) revenue Data base i-e Active Tax Payer List (Sales Tax)			On ATL	OK
8		The Bidder should also be registered with relevant / concerned Revenue Authority. If not registered, the 100% tax shall be deducted at source as per applicable law and credited to relevant account.			-	OK
9		Bidder shall be held non-responsive if Bidder's name is found in Schedule-IV (https://nacta.gov.pk/proscribed-persons-2/) and list of organizations / Splinter Outfits https://nacta.gov.pk/proscribed-organizations/ notified by National Counter Terrorism Authority NACTA Pakistan.			submitted	OK
10		Minimum two (2) works (supply & installation of AC's) of cost 1.0 Million or more each, executed during last 5 (five) years (Work order/ completion certificates to be attached).			Work orders submitted	OK
11		Minimum available liquid assets of Rs. 400,000/- (Bank statement of three months printed between date of publication of tender notice and bid submission date) be submitted as evidence showing required balance at			Bank statement submitted	OK


Evaluation Criteria				Submissions/ Compliance by the Bidders		
Sr. No	Category	Criteria	Minimum Acceptable	Document/ Evidence Required	M/s. Climate Control	
					Submittal	Remarks
		any one instant in the statement of last three months				
12		Acceptance of the Proposed Work Program as given in Schedule-E to Bid or submission of Work Program proposed by the bidder with overall project duration as mentioned in the contract data.				OK
		Technical Compliance with Annexure – A				
13		The offered equipment must technically comply with minimum technical specification listed in Annexure – A, standards and requirements mentioned in specifications and Schedule-A to Bid Vol-II (Schedule of Prices / Financial Bid) of bid document. The bidders shall submit the technical brochure of the offered equipment.			Brochure Attached	OK
		Responsiveness				Responsive


Summaira Kaleem
 Member
 ACM


Masra Jaral
 Member
 ACM


Muhammad Atta Jilani
 Member
 ACM



Nehdia Khalid
 Member
 ACM



Azhar Iqbal
 Chairperson
 (CO)


ANNEXURE A – MINIMUM TECHNICAL REQUIREMENTS


Technical Compliance Standards


S.No	Item Description	SBP Requirement	M/s Climate Control
	Minimum Capacity (BTU/hr)	4.0 TR – 48,000 BTU/hr Conventional Heat & cool Type	4.0 TR – 48,000 BTU/hr Conventional Heat & cool Type
	Minimum Energy Efficiency Ratio EER (W/W)	<u>Conventional Type AC's</u> EER must be greater than or equal to 2.7	3.01
1	$EER = \frac{\text{Cooling output (W)}}{\text{Power Input (W)}}$		
2	Minimum Warranty for Compressor	3 Years	03 years
3	Minimum Warranty for Parts	1 Year	01 year
4	Offered Brand & Model #	None	PEL(PFSAC-48K)
Responsiveness			Responsive


Summaira Kaleem
Member
ACM


Masra Jaral
Member
ACM


Muhammad Atta Jilani
Member
ACM


Nehdia Khalid
Member
ACM


Azhar Iqbal
Chairperson
(CO)