



NATIONAL INSTITUTE OF BANKING AND FINANCE ISLAMABAD

Supply, installation, testing and commissioning of Booster Pump control panel at NIBAF Islamabad

TECHNICAL BID EVALUATION REPORT

Name of Procuring Agency	National Institute of Banking and Finance Pakistan, Islamabad
Method of procurement	PPRA Rule 36 b (Single Stage-Two Envelop Procedure)
Title of Procurement	Supply, installation, testing and commissioning of Booster Pump control panel at NIBAF Islamabad
PPRA Ref. No. (TSE)	TS551408E
Date & Time of Bid Closing	12-12-2024 till 11:00 AM
Date & Time of Bid Opening	12-12-2024 at 11:30 AM
No. of Tenders issued to bidders	Tender through EPADS




EVALUATION CRITERIA			SUBMISSION/COMPLIANCE BY THE BIDDERS			
			M/s SISCO TECHNICAL SERVICES		M/s S & S Engineering Services	
Sr No	Eligibility / Qualification Criteria	Annexure / Page	Submitted	Remarks	Submitted	Remarks
1	Conditional / Un-conditional Bid is un-conditional, conditional bids shall be rejected.		As per bid document	Ok	As per bid document	Ok
2	Bid Security Bid Security is required as per Clause ITB-18.1. Bid Security in Original is to be attached with Technical Proposal.		Received	Ok	Received	Ok
3	Income Tax and General Sales Tax Bidder must be registered with FBR in Income Tax and General Sales Tax and must active taxpayer as per Federal Board of Revenue (FBR's) revenue Data base i-e Active Tax Payer List.		Received	Ok	Registered	Ok
4	Revenue Authority Registration The Bidder should also be registered with relevant / concerned Revenue Authority. If not registered, the 100% tax shall be deducted at source as per applicable law and credited to relevant account.		Received	Ok	Registered	Ok
5	Company Registration i. Name of Company ii. Company Legal Status: (Tick Anyone and provide relevant documents) 1. In case of Individual / Sole Proprietor a) Copy of CNIC b) Affidavit that firm is individual / Sole proprietor 2. In case of Associated of Persons (AOP) a) Partnership Deed b) No. of Partners along with CNIC 3. In case of (Pvt.) limited a) Copy of Article of Association / Memorandum b) Form 29, Form A and Nos of Directors along with copy of CNIC iii. Contact details, Telephone, Mobile No. , Fax numbers(if any), email address (if any) Postal Address		Received	Ok	Received	Ok
6	Undertaking (As per Form – T4 attached) The bidder is required to submit an undertaking on stamp paper of Rs.100/- as per format provided in Form – T4.		Received	Ok	Received	Ok
7	Experience Minimum two (2) jobs of similar nature and complexity (pump control panels) executed during last 5 (five) years (Work order/ completion certificates to be attached). OR Minimum two (2) electrical works each amounting to Rs. 1M executed during last 5 (five) years (Work order/ completion certificates to be attached).		Received	Ok	Received	Ok
8	Financial Capability/Liquid Assets Available Financial Capability/Liquid Assets of (Rs. 500,000/-) or above. a. Bank statement be submitted as evidence showing required balance at any one instant in the statement of last three months prior to publication of tender notice, b. Available Bank Credit Line facility or c. Liquid Assets		Received	Ok	Submitted	Ok
9	Acceptance of the Proposed Work Program as given in document or Work Program proposed by the bidder with overall project duration as mentioned in the contract data.		Received	Ok	Submitted	Ok
10	Technical Compliance with Annexure – A The offered equipment must technically comply with the minimum technical specification listed in Annexure – A of the Bid. The Bidder shall submit technical brochures and component satisfying that the offered equipment complies with the standard listed in Annexure-A.		Received	Ok	Received	Ok
In view of the Bidder's Eligibility / Qualification Criteria, the bid has been found;			Responsive		Responsive	

Assistant Executive Engineer

Deputy Director

Joint Director

ANNEXURE A – MINIMUM TECHNICAL REQUIREMENTS

Title of Procurement		Supply, installation, testing and commissioning of Booster Pump control panel at NIBAF Islamabad		
PPRA Ref. No. (TSE)		TS551408E		
Technical Compliance Standards				
S.No	Item Description	Requirement	Compliance by the Bidder	
			M/s SISCO TECHNICAL SERVICES	M/s S & S Engineering Services
	Automatic Control Panel			
1	Booster Control	1.5-3P, 230VAC, IP20, 50Hz for KSB Movitec VF 25/4 B, 7.5kW (6.68kW) or equivalent	Ok	Ok
2	Components of Automatic Control Panel with Pressure	VFD, 7.5kW /10HP, IN: 3x 380-480V 50Hz 25.6/22.1A OUT: 3x0-Vin 0-400Hz 15.5/14.0A (Make Danfoss/equivalent)	Ok	Ok
	Control and VFD	MCCB 3-Pole, 60A, 10KVA, 380/415V as per IEC 60947-2, 01 Nos		
		Motor Circuit Breakers Type GV0ME32, adjustment range 24~32A, 01Nos		
		Motor Circuit Breakers Type GV0ME20, adjustment range 24~32A, 04Nos		
		Magnetic Contactor 05 Nos, Type LC1D18 (18A), 06 Nos		
		Under and Over Voltage protection 3phase 380~480V Ac		
3	Pressure transducer /other components for new control panel installation.	Suitable for Movitec VF 25/4 B, 7.5kW (6.68kW) Booster Control System and VFD as above	Ok	Ok
Technical Compliance with Annexure – A			Compliant	Compliant
<div><div> Assistant Executive Engineer</div><div> Deputy Director</div><div> Joint Director</div></div>				